


A. Site Energy Production Summary*

	Energy Production (kWh)					3
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	WTG 1	WTG 2	WTG 3	
Apr-24	1,335,000	696,296	320,266	107,262	268,768	
May-24	1,106,000	0				
Jun-24	836,000	0				
Jul-24	694,000	0				
Aug-24	619,000	0				
Sep-24	839,000	0				
Oct-24	1,294,000	0				
Nov-24	1,428,000	0				
Dec-24	1,459,000	0				
Jan-25	1,589,000	0				
Feb-25	1,306,000	0				
Mar-25	1,331,000	0				
Apr-25	1,335,000	0				
Production 2024 (ytd) (kWh)	1,335,000	696,296	320,266	107,262	268,768	
Total Production (LTM) (kWh)	-	-	-	-	-	
Capacity Factor (LTM) ¹	-		*Value calculated over the last 12 months			

B. Site Energy Production Graph

April-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-24	500hour Maintenance	~20	WTG 1
May-24	500hour Maintenance	~20	WTG 2
May-24	500hour Maintenance	~20	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/27/2024-430/2024	Turbine Fault	Unplanned	62.43	WTG 2

F. Turbine Downtime ²

Downtime (hr)	This Month	Year To Date
WTG 1		0.00
WTG 2	62.43	62.43
WTG 3	7.79	7.79
Total	70.22	70.22

G. Billed Data

Meter Reading (Date/Time)	5/1/2024 12:00 AM
Meter To Date Produced	694,469
Meter To Date Consumed	3,633
Last Reading Produced	232,581
Last Reading Consumed	3,037
Billed kWh	461,292 kWh
Next Meter Reading	6/1/2024 12:00 AM

H. Report Notes and Comments

¹ Capacity factor to be included once full year of data is available.

² Turbine Availability/Downtime Pending.

³ Turbines were actively generating starting these days:
WTG 1 - April 10
WTG 2 - April 18
WTG 3 - April 9
Energy generation was billed to the customer starting April 18, 2024