


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
May-23	980,450	753,863	252,701	233,602	267,560
Jun-23	649,158	683,362	231,589	228,457	223,316
Jul-23	618,687	440,827	132,214	148,791	159,822
Aug-23	559,508	555,831	128,322	211,051	216,458
Sep-23	603,085	353,794	138,579	132,576	82,639
Oct-23	967,926	1,001,240	338,432	337,485	325,323
Nov-23	1,362,692	1,373,200	473,833	450,348	449,019
Dec-23	1,254,397	1,184,353	403,749	399,895	380,709
Jan-24	1,290,968	1,381,482	471,543	462,558	447,381
Feb-24	1,170,349	1,107,267	415,523	340,449	351,295
Mar-24	1,227,217	1,574,190	537,888	515,417	520,885
Apr-24	1,438,497	1,440,355	491,796	461,645	486,914
May-24	980,450	836,173	284,799	275,439	275,935
Production 2024 (ytd) (kWh)	6,107,481	6,339,467	2,201,549	2,055,508	2,082,410
Total Production (LTM) (kWh)	12,122,935	11,932,074	4,048,267	3,964,111	3,919,696
Capacity Factor (LTM)	30.19%				

B. Site Energy Production Graph

May-2024



Monthly Report

May-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2024	11.5 Year Maintenance	~8	WTG 1
June-2024	11.5 Year Maintenance	~8	WTG 2
June-2024	11.5 Year Maintenance	~8	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WTG 1	0.00	62.31
WTG 2	0.00	152.36
WTG 3	0.00	124.75
Total	0.00	339.42

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2024 Annual
WTG 1	4.94	4.94
WTG 2	4.90	4.90
WTG 3	4.97	4.97
Estimated	13.57	13.39

Capacity Factor (%)	This Month	2024 Annual
WTG 1	25.52%	42.25%
WTG 2	24.73%	41.45%
WTG 3	24.68%	40.09%
Low Estimate	28.39%	28.72%

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.