



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
May-23	311,000	214,744
Jun-23	228,000	169,424
Jul-23	179,000	116,572
Aug-23	157,000	139,977
Sep-23	224,000	93,945
Oct-23	338,000	245,587
Nov-23	402,000	324,788
Dec-23	403,000	257,014
Jan-24	460,000	266,509
Feb-24	372,000	77 ²
Mar-24	417,000	0 ²
Apr-24	399,000	71,938
May-24	311,000	176,362
Production 2024 (ytd) (kWh)	1,959,000	514,886
Total Production (LTM) (kWh)	3,890,000	1,862,193
Capacity Factor (LTM)	14.13%	

B. Site Energy Production Graph

May-2024



Monthly Report

May-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2024	8 Year Preventive Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
H1	10.73	2224.84

G. Billed Data

Meter Reading (Date/Time)	5/25/2024 12:00 AM
Meter To Date Produced	26,159,410 kWh
Meter To Date Consumed	99,509 kWh
Last Reading Produced	25,975,452 kWh
Last Reading Consumed	98,550 kWh
Billed kWh	182,999 kWh
Next Meter Reading	6/26/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024-March 2024 other than 77kWh for testing.