



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jul-23	179,000	116,572
Aug-23	157,000	139,977
Sep-23	224,000	93,945
Oct-23	338,000	245,587
Nov-23	402,000	324,788
Dec-23	403,000	257,014
Jan-24	460,000	266,509
Feb-24	372,000	77 ²
Mar-24	417,000	0 ²
Apr-24	399,000	71,938
May-24	311,000	176,362
Jun-24	228,000	182,891
Jul-24	179,000	130,160
Production 2024 (ytd) (kWh)	2,366,000	827,937
Total Production (LTM) (kWh)	3,890,000	1,889,248
Capacity Factor (LTM)	14.34%	

B. Site Energy Production Graph

July-2024



Monthly Report

July-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
August-2024	8 Year Preventive Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
H1	3.17	2251.09

G. Billed Data

Meter Reading (Date/Time)	7/26/2024 12:00 AM
Meter To Date Produced	26,488,525 kWh
Meter To Date Consumed	102,007 kWh
Last Reading Produced	26,348,043 kWh
Last Reading Consumed	100,562 kWh
Billed kWh	139,037 kWh
Next Meter Reading	8/24/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024-March 2024 other than 77kWh for testing.