


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Jul-23	638,097	331,312	124,906	135,529	70,877
Aug-23	577,992	642,748	209,098	212,029	221,621
Sep-23	631,697	463,267	154,792	153,657	154,818
Oct-23	1,003,602	1,091,106	381,773	348,712	360,621
Nov-23	1,395,914	1,358,931	475,875	461,556	421,500
Dec-23	1,278,858	1,094,994	354,430	371,945	368,619
Jan-24	1,332,437	1,291,710	437,812	434,202	419,696
Feb-24	1,157,019	1,212,723	415,829	388,526	408,368
Mar-24	1,242,761	1,577,430	527,008	516,861	533,561
Apr-24	1,447,248	1,470,775	495,877	478,795	496,103
May-24	1,010,966	862,575	288,229	287,713	286,633
Jun-24	668,411	942,158	314,570	308,308	319,280
Jul-24	638,097	496,566	168,933	163,396	164,237
Production 2024 (ytd) (kWh)	7,496,938	7,853,937	2,648,258	2,577,801	2,627,878
Total Production (LTM) (kWh)	12,385,000	12,504,983	4,224,226	4,125,700	4,155,057
Capacity Factor (LTM)	31.64%				

B. Site Energy Production Graph



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2024	12 Year Maintenance	~15	WTG A
November-2024	12 Year Maintenance	~15	WTG B
November-2024	12 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WTG A	0.89	161.50
WTG B	0.74	112.17
WTG C	0.63	143.64
Total	2.26	417.31

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	8.41	12.17
WTG B	8.28	11.91
WTG C	8.95	12.81
Estimated	11.22	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	15.14%	34.54%
WTG B	14.64%	33.62%
WTG C	14.72%	34.27%
Low Estimate	18.03%	28.72%

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.