


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jul-23	609,000	360,370	124,670	123,847	111,853
Aug-23	534,000	594,879	204,225	207,630	183,024
Sep-23	736,000	400,037	139,966	142,124	117,947
Oct-23	1,131,000	1,024,588	350,783	351,133	322,672
Nov-23	1,281,000	1,328,497	453,156	447,161	428,180
Dec-23	1,263,000	1,020,636	343,379	344,554	332,703
Jan-24	1,433,000	837,413	281,008	279,606	276,799
Feb-24	1,213,000	0	0	0	0
Mar-24	1,339,000	0	0	0	0
Apr-24	1,327,000	57	0	0	57
May-24	1,052,000	0	0	0	0
Jun-24	751,000	36,320	0	36,320	0
Jul-24	609,000	287,904	40,900	158,129	88,875
Production 2024 (ytd) (kWh)	7,724,000	1,161,694	321,908	474,055	365,731
Total Production (LTM) (kWh)	12,669,000	5,530,331	1,813,417	1,966,657	1,750,257
Capacity Factor (LTM)	13.99%				

B. Site Energy Production Graph

July-2024



Monthly Report

July-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2024	4 Year Preventive Maintenance	~15	L1
September-2024	4 Year Preventive Maintenance	~15	L2
September-2024	4 Year Preventive Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/1/2024-7/18/2024	Fleet Retrofit	Unplanned	425.7	L1
7/1/2024-7/10/2024	Fleet Retrofit	Unplanned	226.45	L3

F. Turbine Downtime²

Downtime (hr)	This Month	Year To Date
L1	425.70	4331.06
L2	5.84	3848.90
L3	229.35	4134.56
Total	660.89	12314.52

G. Billed Data

Meter Reading (Date/Time)	7/26/2024 12:00 AM
Meter To Date Produced	40,874,203 kWh
Meter To Date Consumed	194,648 kWh
Last Reading Produced	40,626,133 kWh
Last Reading Consumed	189,126 kWh
Billed kWh	242,548 kWh
Next Meter Reading	8/24/2024 12:00 AM

H. Report Notes and Comments

¹ Nov totals updated from the report published Jan 18, 2024 due to an error found in the SCADA data.

² Turbine Availability/Downtime Pending.

³ As a result of previously disclosed circumstances, other than 57kWh for testing. The project had no energy production from February 2024 - May 2024..

⁴ As a result of previously disclosed circumstances, L1, and L3 had no energy production February 2024 - June 2024.