


A. Site Energy Production Summary*

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	WTG 1	WTG 2	WTG 3	
Apr-24	1,335,000	696,296	320,266	107,262	268,768	3
May-24	1,106,000	725,087	270,871	206,159	248,057	
Jun-24	836,000	766,124	281,287	214,562	270,275	
Jul-24	694,000	444,201	169,239	124,259	150,703	
Aug-24	619,000	0				
Sep-24	839,000	0				
Oct-24	1,294,000	0				
Nov-24	1,428,000	0				
Dec-24	1,459,000	0				
Jan-25	1,589,000	0				
Feb-25	1,306,000	0				
Mar-25	1,331,000	0				
Apr-25	1,335,000	0				
Production 2024 (ytd) (kWh)	3,971,000	2,631,708	1,041,663	652,242	937,803	
Total Production (LTM) (kWh)	-	-	-	-	-	
Capacity Factor (LTM) ¹	- *Value calculated over the last 12 months					

B. Site Energy Production Graph

July-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
Aug-24	500hour Maintenance	~20	WTG 1
Aug-24	500hour Maintenance	~20	WTG 2
Aug-24	500hour Maintenance	~20	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/2/2024	Testing	Unplanned	5.80	WTG 1,WTG 2,WTG 3
7/12/2024	Grid Fault	Unplanned	10.04	WTG 1
7/12/2024	Grid Fault	Unplanned	10.11	WTG 2
7/12/2024	Grid Fault	Unplanned	9.89	WTG 3
7/23/2024	500hour Maintenance	Planned	0.84	WTG 1, WTG 2
7/23/2024	500hour Maintenance	Planned	4.88	WTG 3
7/24/2024	500hour Maintenance	Planned	2.75	WTG 1
7/24/2024	500hour Maintenance	Planned	3.89	WTG 2
7/30/2024	500hour Maintenance	Planned	4.75	WTG 1
7/31/2024	500hour Maintenance	Planned	1.45	WTG 1
7/31/2024	500hour Maintenance	Planned	4.58	WTG 2

F. Turbine Downtime ²

Downtime (hr)	This Month	Year To Date
WTG 1	28.15	37.73
WTG 2	27.97	93.47
WTG 3	20.57	40.05
Total	76.69	171.25

G. Billed Data

Meter Reading (Date/Time)	8/1/2024 12:00 AM
Meter To Date Produced	2,596,065
Meter To Date Consumed	16,440
Last Reading Produced	2,161,413
Last Reading Consumed	10,697
Billed kWh	428,909 kWh
Next Meter Reading	9/1/2024 12:00 AM

H. Report Notes and Comments

¹ Capacity factor to be included once full year of data is available.

² Turbine Availability/Downtime Pending.

³ Turbines were actively generating starting these days:

WTG 1 - April 10

WTG 2 - April 18

WTG 3 - April 9

Energy generation was billed to the customer starting April 18, 2024