


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Jul-23	351,000	239,451	127,232	112,219
Aug-23	303,000	352,751	170,780	181,971
Sep-23	431,000	226,645	110,485	116,160
Oct-23	674,000	582,309	277,729	304,580
Nov-23	796,000	809,264	396,263	413,001
Dec-23	820,000	637,044	312,365	324,679
Jan-24	931,000	604,549	291,738	312,811
Feb-24	737,000	0	0	0
Mar-24	777,000	0	0	0
Apr-24	722,000	0	0	0
May-24	564,000	0	0	0
Jun-24	422,000	26,106	0	26,106
Jul-24	351,000	270,166	124,029	146,137
Production 2024 (ytd) (kWh)	4,504,000	900,821	415,767	485,054
Total Production (LTM) (kWh)	7,528,000	3,508,834	1,683,389	1,825,445
Capacity Factor (LTM)	13.32%			

B. Site Energy Production Graph

July-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
August-2024	5.5 Year Maintenance	~8	V1
August-2024	5.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/1/2024	Fleet Retrofit	Unplanned	5.94	V1

F. Downtime¹

Downtime (hr)	This Month	Year To Date
V1	11.25	3900.96
V2	4.16	3800.50
Total	15.41	7701.46

G. Billed Data

Meter Reading (Date/Time)	8/1/2024 12:00 AM
Meter To Date Produced	38,949,379 kWh
Meter To Date Consumed	113,056 kWh
Last Reading Produced	38,690,536 kWh
Last Reading Consumed	110,253 kWh
Billed kWh	256,040 kWh
Next Meter Reading	9/1/2024 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending.

²As a result of previously disclosed circumstances, the project had no energy production February 2024 - May 2024.

³As a result of previously disclosed circumstances, V1 had no energy production February 2024 - June 2024.