


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Jul-23	527,000	311,849	99,568	102,035	110,246
Aug-23	449,000	398,914	133,449	128,288	137,177
Sep-23	610,000	267,906	86,932	83,577	97,397
Oct-23	990,000	700,059	243,485	220,958	235,616
Nov-23	1,123,000	964,114	331,159	307,588	325,367
Dec-23	1,153,000	869,834	302,229	280,586	287,019
Jan-24	1,306,000	771,163	268,921	247,627	254,615
Feb-24	1,137,000	0	0	0	0
Mar-24	1,134,000	0	0	0	0
Apr-24	1,176,000	269,672	87,026	88,258	94,388
May-24	927,000	533,339	180,109	172,157	181,073
Jun-24	634,000	512,583	178,220	152,008	182,355
Jul-24	527,000	347,033	118,853	106,389	121,791
Production 2024 (ytd) (kWh)	6,841,000	2,433,790	833,129	766,439	834,222
Total Production (LTM) (kWh)	11,166,000	5,634,617	1,930,383	1,787,436	1,916,798
Capacity Factor (LTM)	14.25%				

B. Site Energy Production Graph

July-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
August-2024	6.5 Year Preventive Maintenance	~8	W1
August-2024	6.5 Year Preventive Maintenance	~8	W2
August-2024	6.5 Year Preventive Maintenance	~8	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/1/2024-7/2/2024	Turbine Fault	Unplanned	30.61	W2

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
W1	2.88	2212.23
W2	30.61	2280.84
W3	2.80	2249.13
Total	36.29	6742.20

G. Billed Data

Meter Reading (Date/Time)	7/21/2024 12:00 AM
Meter To Date Produced	58,835,602 kWh
Meter To Date Consumed	197,834 kWh
Last Reading Produced	58,387,406 kWh
Last Reading Consumed	194,227 kWh
Billed kWh	444,589 kWh
Next Meter Reading	8/21/2024 12:00 AM

H. Report Notes and Comments

¹Turbine Availability/Downtime Pending

²As a result of previously disclosed circumstances, the project had no energy prodction February 2024-March 2024.