



BALL CORPORATION - ZEPHYR WIND PROJECT


North Findlay Wind Campus, Findlay, OH

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Aug-16	614,000	473,979	159,038	156,929	158,012
Sep-16	529,000	646,651	220,330	208,987	217,334
Oct-16	992,000	931,925	303,980	309,926	318,019
Nov-16	1,295,000	1,209,020	415,317	397,636	396,067
Dec-16	1,565,000	1,428,145	509,779	450,115	468,251
Jan-17	1,325,000	1,304,579	450,536	420,186	433,857
Feb-17	1,391,000	1,372,648	473,614	443,979	455,055
Mar-17	1,229,000	1,339,090	447,685	437,432	453,973
Apr-17	1,453,000	1,263,804	425,766	415,442	422,596
May-17	924,000	1,123,269	395,614	347,574	380,081
Jun-17	645,000	952,539	334,400	300,615	317,524
Jul-17	586,000	453,808	163,793	151,302	138,713
Aug-17	614,000	448,585	157,969	145,785	144,831
Production 2017 (ytd) (kWh)	8,167,000	8,258,322	2,849,377	2,662,315	2,746,630
Total Production (kWh)*	12,548,000	12,474,063	4,298,783	4,028,979	4,146,301
Capacity Factor*	31.64%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

August-2017



Monthly Report

August-2017



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
September-2017	Goldwind 1.5 Year Maintenance	~15	Z1
September-2017	Goldwind 1.5 Year Maintenance	~15	Z2
September-2017	Goldwind 1.5 Year Maintenance	~15	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/3/2017	Shutdown for Contractors	Unplanned	9.96	Z1, Z2, Z3
8/7/2017	Shutdown for Contractors	Unplanned	10.93	Z1
8/9/2017	Shutdown for Contractors	Unplanned	8.02	Z1
8/9/2017	Shutdown for Contractors	Unplanned	6.77	Z2
8/9/2017	Shutdown for Contractors	Unplanned	8.02	Z3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	100.00%	99.10%
Z2	99.69%	98.22%
Z3	99.28%	99.58%
Avg	99.66%	98.96%

Downtime (hr)	This Month	Year To Date
Z1	36.94	165.45
Z2	26.23	238.24
Z3	30.57	144.99
Total	93.74	548.68

G. Billed Data

Meter Reading (Date/Time)	8/17/2017 12:00 AM
Meter To Date Produced	18,473,288 kWh
Meter To Date Consumed	21,077 kWh
Last Reading Produced	18,115,592 kWh
Last Reading Consumed	19,322 kWh
Billed kWh	355,941 kWh
Next Meter Reading	9/17/2017 12:00 AM

H. Report Notes and Comments

**Goldwind 1.5 year maintenance moved to September-2017.