



BALL CORPORATION - ZEPHYR WIND PROJECT


North Findlay Wind Campus, Findlay, OH

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Sep-16	529,000	646,651	220,330	208,987	217,334
Oct-16	992,000	931,925	303,980	309,926	318,019
Nov-16	1,295,000	1,209,020	415,317	397,636	396,067
Dec-16	1,565,000	1,428,145	509,779	450,115	468,251
Jan-17	1,325,000	1,304,579	450,536	420,186	433,857
Feb-17	1,391,000	1,372,648	473,614	443,979	455,055
Mar-17	1,229,000	1,339,090	447,685	437,432	453,973
Apr-17	1,453,000	1,263,804	425,766	415,442	422,596
May-17	924,000	1,123,269	395,614	347,574	380,081
Jun-17	645,000	952,539	334,400	300,615	317,524
Jul-17	586,000	453,808	163,793	151,302	138,713
Aug-17	614,000	448,585	157,969	145,785	144,831
Sep-17	529,000	440,963	153,200	143,235	144,528
Production 2017 (ytd) (kWh)	8,696,000	8,699,285	3,002,577	2,805,550	2,891,158
Total Production (kWh)*	12,548,000	12,268,375	4,231,653	3,963,227	4,073,495
Capacity Factor*	31.12%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

September-2017



Monthly Report

September-2017



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
September-2017	Goldwind 1.5 Year Maintenance	~15	Z1
September-2017	Goldwind 1.5 Year Maintenance	~15	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
9/5-9/7/2017	Shutdown for Contractors	Unplanned	41.41	Z1, Z2, Z3
9/12-9/13/2017	Shutdown for Contractors	Unplanned	26.45	Z1, Z2, Z3
9/25-9/26/2017	Goldwind 1.5 Year Maintenance	Planned	9.71	Z2
9/28/2017	Goldwind 1.5 Year Maintenance	Planned	4.63	Z3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	99.98%	99.20%
Z2	98.87%	98.29%
Z3	98.38%	99.45%
Avg	99.08%	98.98%

Downtime (hr)	This Month	Year To Date
Z1	72.13	237.58
Z2	90.05	328.29
Z3	88.26	233.25
Total	250.44	799.12

G. Billed Data

Meter Reading (Date/Time)	9/16/2017 12:00 AM
Meter To Date Produced	18,986,561 kWh
Meter To Date Consumed	22,336 kWh
Last Reading Produced	18,473,288 kWh
Last Reading Consumed	21,077 kWh
Billed kWh	512,015 kWh
Next Meter Reading	10/16/2017 12:00 AM

H. Report Notes and Comments

**Goldwind 1.5 year maintenance for Z1 and the completion of Z3 moved to October-2017.