




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Nov-16	1,395,914	1,417,200	491,080	464,290	461,830
Dec-16	1,278,858	1,765,070	595,620	592,130	577,320
Jan-17	1,332,437	1,587,840	547,800	521,640	518,400
Feb-17	1,157,019	1,601,650	550,370	513,360	537,920
Mar-17	1,242,761	1,682,140	564,140	545,320	572,680
Apr-17	1,447,248	1,676,860	570,960	544,340	561,560
May-17	1,010,966	1,309,614	447,560	424,304	437,750
Jun-17	668,411	1,199,560	427,710	365,940	405,910
Jul-17	638,097	608,374	208,860	199,814	199,700
Aug-17	577,992	550,820	193,760	179,770	177,290
Sep-17	631,697	605,096	208,710	201,632	194,754
Oct-17	1,003,602	1,223,590	422,370	411,740	389,480
Nov-17	1,395,914	1,441,140	493,690	470,470	476,980
Production 2017 (ytd) (kWh)	11,106,141	13,486,684	4,635,930	4,378,330	4,472,424
Total Production (kWh)*	12,384,999	15,251,754	5,231,550	4,970,460	5,049,744
Capacity Factor*	38.69%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

November-2017



Monthly Report
November-2017



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
December-2017	Goldwind 5.5 Year Maintenance	~8	WTG A
December-2017	Goldwind 5.5 Year Maintenance	~8	WTG B
December-2017	Goldwind 5.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events - November 2017

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
------	-------	-------------------	---------------	---------

F. Turbine Availability & Downtime

Availability (%)	This Month	Year to Date
WTG A	99.85%	99.22%
WTG B	100.00%	99.07%
WTG C	100.00%	99.23%
Avg	99.95%	99.17%

Downtime (hr)	This Month	Year to Date
WTG A	4.85	249.54
WTG B	4.53	255.84
WTG C	3.77	221.16
Total	13.15	726.54

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2017 Annual
WTG A	13.35	12.92
WTG B	13.48	12.83
WTG C	14.00	13.40
Estimated	15.58	13.39

Capacity Factor (%)	This Month	2017 Annual
WTG A	45.71%	38.91%
WTG B	43.56%	36.74%
WTG C	44.16%	37.53%
Low Estimate	41.95%	37.73%

H. Report Notes and Comments

*Goldwind 5.5 year maintenance moved to December-2017