




A. Site Energy Production Summary**

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Nov-17	1,123,000	466,686	-	-	-
Dec-17	1,153,000	852,755	-	-	-
Jan-18	1,306,000	1,214,611	405,820	399,594	409,197
Feb-18	1,137,000	881,991	301,494	285,462	295,035
Mar-18	1,134,000	-	-	-	-
Apr-18	1,176,000	-	-	-	-
May-18	927,000	-	-	-	-
Jun-18	634,000	-	-	-	-
Jul-18	527,000	-	-	-	-
Aug-18	449,000	-	-	-	-
Sep-18	610,000	-	-	-	-
Oct-18	990,000	-	-	-	-
Nov-18	1,123,000	-	-	-	-
Production 2018 (ytd) (kWh)	2,443,000	2,096,602	707,314	685,056	704,232
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	-		*Value calculated over the last 12 months		

B. Site Energy Production Graph

February-2018



Monthly Report
February-2018

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2018	Goldwind 6 Month Maintenance	~8	W1
May-2018	Goldwind 6 Month Maintenance	~8	W2
May-2018	Goldwind 6 Month Maintenance	~8	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/4-2/5/2018	Icing Event	Unplanned	23.59	W1
2/6-2/7/2018	Icing Event	Unplanned	21.06	W1, W2
2/11-2/12/2018	Icing Event	Unplanned	7.99	W3
2/12/2018	Anchor Bolt Tensioning	Planned	8.26	W2
2/13-2/14/2018	Grid Fault	Unplanned	9.36	W1
2/13-2/14/2018	Grid Fault	Unplanned	10.30	W2
2/13-2/14/2018	Grid Fault	Unplanned	11.79	W3
2/15/2018	Converter Cooling Fan Error	Unplanned	4.54	W2
2/15/2018	Grid Fault	Unplanned	4.34	W3
2/22/2018	Icing Event	Unplanned	7.17	W1
2/22/2018	Icing Event	Unplanned	7.84	W2
2/22/2018	Icing Event	Unplanned	9.77	W3
2/25/2018	Icing Event	Unplanned	4.81	W1, W2, W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.81%	99.91%
W2	98.73%	99.34%
W3	99.61%	99.80%
Avg	99.39%	99.68%

Downtime (hr)	This Month	Year To Date
W1	73.36	179.75
W2	65.41	148.40
W3	43.44	104.60
Total	182.21	432.75

G. Billed Data

Meter Reading (Date/Time)	2/20/2018 12:00 AM
Meter To Date Produced	3,020,294 kWh
Meter To Date Consumed	8,084 kWh
Last Reading Produced	2,243,035 kWh
Last Reading Consumed	2,794 kWh
Billed kWh	771,969 kWh
Next Meter Reading	3/20/2018 12:00 AM

H. Report Notes and Comments

**Nov-17 and Dec-17 production data read from meter. Capacity factor will be included once a year of data has been collected.