




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Mar-17	1,242,761	1,682,140	564,140	545,320	572,680
Apr-17	1,447,248	1,676,860	570,960	544,340	561,560
May-17	1,010,966	1,309,614	447,560	424,304	437,750
Jun-17	668,411	1,199,560	427,710	365,940	405,910
Jul-17	638,097	608,374	208,860	199,814	199,700
Aug-17	577,992	550,820	193,760	179,770	177,290
Sep-17	631,697	605,096	208,710	201,632	194,754
Oct-17	1,003,602	1,223,590	422,370	411,740	389,480
Nov-17	1,395,914	1,441,140	493,690	470,470	476,980
Dec-17	1,278,858	1,521,630	522,010	495,750	503,870
Jan-18	1,332,437	1,726,420	585,680	568,390	572,350
Feb-18	1,157,019	1,303,000	447,860	426,380	428,760
Mar-18	1,242,761	1,576,970	530,020	505,480	541,470
Production 2018 (ytd) (kWh)	3,732,216	4,606,390	1,563,560	1,500,250	1,542,580
Total Production (kWh)*	12,384,999	14,743,074	5,059,190	4,794,010	4,889,874
Capacity Factor*	37.40%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

March-2018



Monthly Report
March-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
June-2018	Goldwind 6 Year Maintenance	~15	WTG A
June-2018	Goldwind 6 Year Maintenance	~15	WTG B
June-2018	Goldwind 6 Year Maintenance	~15	WTG C

E. Actual Maintenance Events - March 2018

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
3/15/2018	Troubleshooting Anemometer Issues	Unplanned	4.77	WTG B
3/22/2018	Stiffener Installation	Unplanned	5.17	WTG A
3/22/2018	Stiffener Installation	Unplanned	4.64	WTG B
3/23/2018	Stiffener Installation	Unplanned	9.00	WTG B
3/26-3/27/2018	Converter Error	Unplanned	20.44	WTG A

F. Turbine Availability & Downtime

Availability (%)	This Month	Year to Date
WTG A	96.07%	98.49%
WTG B	97.53%	99.15%
WTG C	100.00%	100.00%
Avg	97.86%	99.21%

Downtime (hr)	This Month	Year to Date
WTG A	29.26	84.99
WTG B	18.41	72.28
WTG C	0.00	53.65
Total	47.67	210.92

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2018 Annual
WTG A	14.03	14.29
WTG B	13.80	14.20
WTG C	14.64	14.84
Estimated	14.92	13.39

Capacity Factor (%)	This Month	2018 Annual
WTG A	47.49%	48.26%
WTG B	45.29%	46.30%
WTG C	48.52%	47.61%
Low Estimate	35.10%	47.39%

H. Report Notes and Comments