




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
May-17	1,010,966	1,309,614	447,560	424,304	437,750
Jun-17	668,411	1,199,560	427,710	365,940	405,910
Jul-17	638,097	608,374	208,860	199,814	199,700
Aug-17	577,992	550,820	193,760	179,770	177,290
Sep-17	631,697	605,096	208,710	201,632	194,754
Oct-17	1,003,602	1,223,590	422,370	411,740	389,480
Nov-17	1,395,914	1,441,140	493,690	470,470	476,980
Dec-17	1,278,858	1,521,630	522,010	495,750	503,870
Jan-18	1,332,437	1,726,420	585,680	568,390	572,350
Feb-18	1,157,019	1,303,000	447,860	426,380	428,760
Mar-18	1,242,761	1,576,970	530,020	505,480	541,470
Apr-18	1,447,248	1,316,810	462,450	405,270	449,090
May-18	1,010,966	1,077,570	344,730	377,970	354,870
Production 2018 (ytd) (kWh)	6,190,430	7,000,770	2,370,740	2,283,490	2,346,540
Total Production (kWh)*	12,384,999	14,150,980	4,847,850	4,608,606	4,694,524
Capacity Factor*	35.90%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

May-2018



Monthly Report
May-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2018	Goldwind 6 Year Maintenance	~15	WTG A
June-2018	Goldwind 6 Year Maintenance	~15	WTG B
June-2018	Goldwind 6 Year Maintenance	~15	WTG C

E. Actual Maintenance Events - May 2018

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
5/17/2018	Troubleshooting Warning	Unplanned	6.63	WTG B
5/17/2018	Converter High Voltage Error	Unplanned	11.76	WTG C
5/18/2018	Converter High Voltage Error	Unplanned	8.86	WTG C
5/22/2018	Blade Alignment	Unplanned	7.11	WTG B
5/23/2018	Blade Alignment	Unplanned	6.55	WTG B
5/23/2018	Blade Alignment	Unplanned	10.03	WTG C

F. Turbine Availability & Downtime

Availability (%)	This Month	Year to Date
WTG A	99.91%	98.94%
WTG B	96.91%	98.34%
WTG C	98.65%	99.59%
Avg	98.49%	98.95%

Downtime (hr)	This Month	Year to Date
WTG A	6.61	98.36
WTG B	26.36	137.10
WTG C	35.17	96.34
Total	68.14	331.80

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2018 Annual
WTG A	12.21	13.66
WTG B	12.39	13.61
WTG C	12.97	14.28
Estimated	13.57	13.39

Capacity Factor (%)	This Month	2018 Annual
WTG A	30.89%	43.61%
WTG B	33.87%	42.01%
WTG C	31.80%	43.17%
Low Estimate	28.39%	42.93%

H. Report Notes and Comments