



BALL CORPORATION - ZEPHYR WIND PROJECT


North Findlay Wind Campus, Findlay, OH

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
May-17	924,000	1,123,269	395,614	347,574	380,081
Jun-17	645,000	952,539	334,400	300,615	317,524
Jul-17	586,000	453,808	163,793	151,302	138,713
Aug-17	614,000	448,585	157,969	145,785	144,831
Sep-17	529,000	440,963	153,200	143,235	144,528
Oct-17	992,000	1,058,436	362,133	353,715	342,588
Nov-17	1,295,000	458,432	161,489	151,599	145,344
Dec-17	1,565,000	1,254,048	438,743	412,984	402,321
Jan-18	1,325,000	1,462,888	465,096	513,360	484,432
Feb-18	1,391,000	1,063,264	366,030	354,111	343,123
Mar-18	1,229,000	1,271,280	440,697	415,334	415,249
Apr-18	1,453,000	1,062,956	353,238	350,019	359,699
May-18	924,000	881,519	299,414	291,873	290,232
Production 2018 (ytd) (kWh)	6,322,000	5,741,907	1,924,475	1,924,697	1,892,735
Total Production (kWh)*	12,548,000	10,808,718	3,696,202	3,583,932	3,528,584
Capacity Factor*	27.42%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

May-2018



Monthly Report

May-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2018	Goldwind 2.5 Year Maintenance	~8	Z1
September-2018	Goldwind 2.5 Year Maintenance	~8	Z2
September-2018	Goldwind 2.5 Year Maintenance	~8	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/1/2018	Down Tower Cleaning (Annual Maintenance)	Planned	0.66	Z1
5/1/2018	Down Tower Cleaning (Annual Maintenance)	Planned	0.91	Z2
5/1/2018	Down Tower Cleaning (Annual Maintenance)	Planned	1.16	Z3
5/20/2018	Hydraulic Motor Signal Loss Error	Unplanned	17.70	Z1
5/21/2018	Hydraulic Motor Signal Loss Error	Unplanned	8.81	Z2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	96.38%	96.80%
Z2	100.00%	99.98%
Z3	99.92%	99.64%
Avg	98.77%	98.81%

Downtime (hr)	This Month	Year To Date
Z1	33.39	187.83
Z2	7.49	67.11
Z3	8.36	114.40
Total	49.24	369.34

G. Billed Data

Meter Reading (Date/Time)	5/17/2018 12:00 AM
Meter To Date Produced	27,146,808 kWh
Meter To Date Consumed	30,727 kWh
Last Reading Produced	26,309,580 kWh
Last Reading Consumed	29,532 kWh
Billed kWh	836,033 kWh
Next Meter Reading	6/17/2018 12:00 AM

H. Report Notes and Comments