




A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
May-17	607,000	792,979	401,772	391,207
Jun-17	425,000	675,393	338,704	336,689
Jul-17	385,000	331,091	167,175	163,916
Aug-17	404,000	319,203	161,508	157,695
Sep-17	348,000	337,245	168,680	168,565
Oct-17	653,000	711,340	360,752	350,588
Nov-17	851,000	787,741	386,194	401,547
Dec-17	1,029,000	866,109	435,332	430,777
Jan-18	872,000	1,041,086	531,433	509,653
Feb-18	914,000	718,724	362,629	356,095
Mar-18	808,000	853,902	432,831	421,071
Apr-18	955,000	748,389	381,330	367,059
May-18	607,000	594,897	296,616	298,281
Production 2018 (ytd) (kWh)	4,156,000	3,956,998	2,004,839	1,952,159
Total Production (kWh)*	8,251,000	7,985,120	4,023,184	3,961,936
Capacity Factor*	30.38%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

May-2018



Monthly Report

May-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2018	Goldwind 2 Year Maintenance	~15	W1
June-2018	Goldwind 2 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
5/11/2018	Customer Tour	Unplanned	6.38	W1

F. Turbine Availability & Downtime

Availability	This Month	Annual To Date
W1	100.00%	99.86%
W2	99.97%	99.93%
Avg	99.98%	99.89%

Downtime (hr)	This Month	Annual To Date
W1	12.16	95.78
W2	6.38	80.23
Total	18.54	176.01

G. Billed Data

Meter Reading (Date/Time)	5/28/2018 12:00 AM
Meter To Date Produced	19,309,063 kWh
Meter To Date Consumed	35,793 kWh
Last Reading Produced	18,746,505 kWh
Last Reading Consumed	34,378 kWh
Billed kWh	561,143 kWh
Next Meter Reading	6/28/2018 12:00 AM

H. Report Notes and Comments