




A. Site Energy Production Summary

|                             | Energy Production (kWh) |                   |                                           |           |           |
|-----------------------------|-------------------------|-------------------|-------------------------------------------|-----------|-----------|
|                             | Site                    |                   | By Turbine                                |           |           |
|                             | Expected Production     | Actual Production | WTG A                                     | WTG B     | WTG C     |
| Jul-17                      | 638,097                 | 608,374           | 208,860                                   | 199,814   | 199,700   |
| Aug-17                      | 577,992                 | 550,820           | 193,760                                   | 179,770   | 177,290   |
| Sep-17                      | 631,697                 | 605,096           | 208,710                                   | 201,632   | 194,754   |
| Oct-17                      | 1,003,602               | 1,223,590         | 422,370                                   | 411,740   | 389,480   |
| Nov-17                      | 1,395,914               | 1,441,140         | 493,690                                   | 470,470   | 476,980   |
| Dec-17                      | 1,278,858               | 1,521,630         | 522,010                                   | 495,750   | 503,870   |
| Jan-18                      | 1,332,437               | 1,726,420         | 585,680                                   | 568,390   | 572,350   |
| Feb-18                      | 1,157,019               | 1,303,000         | 447,860                                   | 426,380   | 428,760   |
| Mar-18                      | 1,242,761               | 1,576,970         | 530,020                                   | 505,480   | 541,470   |
| Apr-18                      | 1,447,248               | 1,316,810         | 462,450                                   | 405,270   | 449,090   |
| May-18                      | 1,010,966               | 1,077,570         | 344,730                                   | 377,970   | 354,870   |
| Jun-18                      | 668,411                 | 686,130           | 223,300                                   | 224,540   | 238,290   |
| Jul-18                      | 638,097                 | 499,960           | 165,840                                   | 165,390   | 168,730   |
| Production 2018 (ytd) (kWh) | 7,496,937               | 8,186,860         | 2,759,880                                 | 2,673,420 | 2,753,560 |
| Total Production (kWh)*     | 12,384,999              | 13,529,136        | 4,600,420                                 | 4,432,782 | 4,495,934 |
| Capacity Factor*            | 34.32%                  |                   | *Value calculated over the last 12 months |           |           |

B. Site Energy Production Graph

July-2018



Monthly Report  
July-2018



C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

D. Planned Maintenance Events\*

| Date        | Event                       | Duration (hr) | Turbine |
|-------------|-----------------------------|---------------|---------|
| August-2018 | Goldwind 6 Year Maintenance | ~15           | WTG B   |
| August-2018 | Goldwind 6 Year Maintenance | ~15           | WTG C   |

E. Actual Maintenance Events - July 2018

| Date           | Event                       | Planned/Unplanned | Duration (hr) | Turbine |
|----------------|-----------------------------|-------------------|---------------|---------|
| 7/10-7/11/2018 | Goldwind 6 Year Maintenance | Planned           | 21.76         | WTG A   |
| 7/18/2018      | Goldwind 6 Year Maintenance | Planned           | 2.65          | WTG A   |

F. Turbine Availability & Downtime

| Availability (%) | This Month | Year to Date |
|------------------|------------|--------------|
| WTG A            | 100.00%    | 98.32%       |
| WTG B            | 99.95%     | 98.72%       |
| WTG C            | 99.88%     | 99.68%       |
| Avg              | 99.94%     | 98.91%       |

| Downtime (hr) | This Month | Year to Date |
|---------------|------------|--------------|
| WTG A         | 26.65      | 176.12       |
| WTG B         | 2.60       | 147.37       |
| WTG C         | 3.13       | 102.78       |
| Total         | 32.38      | 426.27       |

G. Wind Speed & Capacity Factor

| Wind Speed (mph) | This Month | 2018 Annual |
|------------------|------------|-------------|
| WTG A            | 8.59       | 12.39       |
| WTG B            | 8.75       | 12.39       |
| WTG C            | 9.39       | 13.08       |
| Estimated        | 11.22      | 13.39       |

| Capacity Factor (%) | This Month | 2018 Annual |
|---------------------|------------|-------------|
| WTG A               | 14.86%     | 36.16%      |
| WTG B               | 14.82%     | 35.03%      |
| WTG C               | 15.12%     | 36.08%      |
| Low Estimate        | 18.03%     | 35.76%      |

H. Report Notes and Comments

\*Annual Maintenance for WTG B and WTG C moved to August-2018