


A. Site Energy Production Summary

|                             | Energy Production (kWh)   |                   |                                           |           |           |
|-----------------------------|---------------------------|-------------------|-------------------------------------------|-----------|-----------|
|                             | Site                      |                   | By Turbine                                |           |           |
|                             | P50 (Expected Production) | Actual Production | Z1                                        | Z2        | Z3        |
| Jul-17                      | 586,000                   | 453,808           | 163,793                                   | 151,302   | 138,713   |
| Aug-17                      | 614,000                   | 448,585           | 157,969                                   | 145,785   | 144,831   |
| Sep-17                      | 529,000                   | 440,963           | 153,200                                   | 143,235   | 144,528   |
| Oct-17                      | 992,000                   | 1,058,436         | 362,133                                   | 353,715   | 342,588   |
| Nov-17                      | 1,295,000                 | 458,432           | 161,489                                   | 151,599   | 145,344   |
| Dec-17                      | 1,565,000                 | 1,254,048         | 438,743                                   | 412,984   | 402,321   |
| Jan-18                      | 1,325,000                 | 1,462,888         | 465,096                                   | 513,360   | 484,432   |
| Feb-18                      | 1,391,000                 | 1,063,264         | 366,030                                   | 354,111   | 343,123   |
| Mar-18                      | 1,229,000                 | 1,271,280         | 440,697                                   | 415,334   | 415,249   |
| Apr-18                      | 1,453,000                 | 1,062,956         | 353,238                                   | 350,019   | 359,699   |
| May-18                      | 924,000                   | 881,519           | 299,414                                   | 291,873   | 290,232   |
| Jun-18                      | 645,000                   | 582,026           | 202,282                                   | 189,017   | 190,727   |
| Jul-18                      | 586,000                   | 427,049           | 144,281                                   | 141,401   | 141,367   |
| Production 2018 (ytd) (kWh) | 7,553,000                 | 6,750,982         | 2,271,038                                 | 2,255,115 | 2,224,829 |
| Total Production (kWh)*     | 12,548,000                | 10,411,446        | 3,544,572                                 | 3,462,433 | 3,404,441 |
| Capacity Factor*            | 26.41%                    |                   | *Value calculated over the last 12 months |           |           |

B. Site Energy Production Graph

July-2018



Monthly Report  
July-2018



C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

D. Planned Maintenance Events

| Date           | Event                         | Duration (hr) | Turbine |
|----------------|-------------------------------|---------------|---------|
| September-2018 | Goldwind 2.5 Year Maintenance | ~8            | Z1      |
| September-2018 | Goldwind 2.5 Year Maintenance | ~8            | Z2      |
| September-2018 | Goldwind 2.5 Year Maintenance | ~8            | Z3      |

E. Actual Maintenance Events

| Date | Event | Planned/Unplanned | Duration (hrs) | Turbine |
|------|-------|-------------------|----------------|---------|
|------|-------|-------------------|----------------|---------|

F. Turbine Availability & Downtime

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| Z1           | 98.52%     | 97.50%       |
| Z2           | 100.00%    | 99.99%       |
| Z3           | 99.97%     | 99.74%       |
| Avg          | 99.50%     | 99.07%       |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| Z1            | 10.98      | 202.09       |
| Z2            | 0.00       | 70.11        |
| Z3            | 0.21       | 117.61       |
| Total         | 11.19      | 389.81       |

G. Billed Data

|                           |                    |
|---------------------------|--------------------|
| Meter Reading (Date/Time) | 7/18/2018 12:00 AM |
| Meter To Date Produced    | 28,262,926 kWh     |
| Meter To Date Consumed    | 33,456 kWh         |
| Last Reading Produced     | 27,770,105 kWh     |
| Last Reading Consumed     | 32,242 kWh         |
| Billed kWh                | 491,607 kWh        |
| Next Meter Reading        | 8/18/2018 12:00 AM |

H. Report Notes and Comments