



BALL CORPORATION - ZEPHYR WIND PROJECT


North Findlay Wind Campus, Findlay, OH

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Aug-17	614,000	448,585	157,969	145,785	144,831
Sep-17	529,000	440,963	153,200	143,235	144,528
Oct-17	992,000	1,058,436	362,133	353,715	342,588
Nov-17	1,295,000	458,432	161,489	151,599	145,344
Dec-17	1,565,000	1,254,048	438,743	412,984	402,321
Jan-18	1,325,000	1,462,888	465,096	513,360	484,432
Feb-18	1,391,000	1,063,264	366,030	354,111	343,123
Mar-18	1,229,000	1,271,280	440,697	415,334	415,249
Apr-18	1,453,000	1,062,956	353,238	350,019	359,699
May-18	924,000	881,519	299,414	291,873	290,232
Jun-18	645,000	582,026	202,282	189,017	190,727
Jul-18	586,000	427,049	144,281	141,401	141,367
Aug-18	614,000	497,290	178,457	162,111	156,722
Production 2018 (ytd) (kWh)	8,167,000	7,248,272	2,449,495	2,417,226	2,381,551
Total Production (kWh)*	12,548,000	10,460,151	3,565,060	3,478,759	3,416,332
Capacity Factor*	26.54% *Value calculated over the last 12 months				

B. Site Energy Production Graph

August-2018



Monthly Report

August-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2018	Goldwind 2.5 Year Maintenance	~8	Z1
September-2018	Goldwind 2.5 Year Maintenance	~8	Z2
September-2018	Goldwind 2.5 Year Maintenance	~8	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/24/2018	DTT Installation/Testing	Unplanned	9.02	Z1,2,3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	100.00%	97.82%
Z2	99.92%	99.98%
Z3	99.89%	99.76%
Avg	99.94%	99.18%

Downtime (hr)	This Month	Year To Date
Z1	18.81	220.90
Z2	19.35	89.46
Z3	19.57	137.18
Total	57.73	447.54

G. Billed Data

Meter Reading (Date/Time)	8/16/2018 12:00 AM
Meter To Date Produced	28,611,715 kWh
Meter To Date Consumed	35,011 kWh
Last Reading Produced	28,262,926 kWh
Last Reading Consumed	33,456 kWh
Billed kWh	347,233 kWh
Next Meter Reading	9/16/2018 12:00 AM

H. Report Notes and Comments