


A. Site Energy Production Summary**

		Energy Production (kWh)					
		Site		By Turbine			
		P50 (Expected Production)	Actual Production	W1	W2	W3	
	Nov-17	1,123,000	466,686	-	-	-	**
	Dec-17	1,153,000	852,755	-	-	-	**
	Jan-18	1,306,000	1,214,611	405,820	399,594	409,197	
	Feb-18	1,137,000	881,991	301,494	285,462	295,035	
	Mar-18	1,134,000	1,184,135	407,384	386,300	390,451	
	Apr-18	1,176,000	996,362	345,950	318,571	331,841	
	May-18	927,000	759,639	251,931	248,291	259,417	
	Jun-18	634,000	418,217	145,680	129,185	143,352	
	Jul-18	527,000	333,148	111,051	106,463	115,634	
	Aug-18	449,000	397,006	132,087	128,358	136,562	***
	Sep-18	610,000	-	-	-	-	
	Oct-18	990,000	-	-	-	-	
	Nov-18	1,123,000	-	-	-	-	
Production 2018 (ytd) (kWh)		7,290,000	6,185,109	2,101,397	2,002,224	2,081,489	
Total Production (kWh)*		-	-	-	-	-	
Capacity Factor*		-		*Value calculated over the last 12 months			

B. Site Energy Production Graph

August-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2018	Goldwind 1 Year Maintenance	~15	W1
October-2018	Goldwind 1 Year Maintenance	~15	W2
October-2018	Goldwind 1 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.56%	99.78%
W2	99.54%	99.42%
W3	99.45%	99.83%
Avg	99.52%	99.68%
Downtime (hr)	This Month	Year To Date
W1	5.45	266.83
W2	5.61	247.70
W3	6.29	193.98
Total	17.35	708.51

G. Billed Data

Meter Reading (Date/Time)	9/20/2018 12:00 AM
Meter To Date Produced	7,108,313 kWh
Meter To Date Consumed	23,605 kWh
Last Reading Produced	6,823,455 kWh
Last Reading Consumed	19,380 kWh
Billed kWh	280,634 kWh
Next Meter Reading	10/20/2018 12:00 AM

H. Report Notes and Comments

**Nov-17 and Dec-17 production data read from meter. Capacity factor will be included once a year of data has been collected.

***August production data includes three days read from meter due to SCADA issue.