




A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Sep-17	348,000	337,245	168,680	168,565
Oct-17	653,000	711,340	360,752	350,588
Nov-17	851,000	787,741	386,194	401,547
Dec-17	1,029,000	866,109	435,332	430,777
Jan-18	872,000	1,041,086	531,433	509,653
Feb-18	914,000	718,724	362,629	356,095
Mar-18	808,000	853,902	432,831	421,071
Apr-18	955,000	748,389	381,330	367,059
May-18	607,000	594,897	296,616	298,281
Jun-18	425,000	410,074	205,521	204,553
Jul-18	385,000	278,804	145,255	133,549
Aug-18	404,000	365,718	185,127	180,591
Sep-18	346,000	399,326	202,515	196,811
Production 2018 (ytd) (kWh)	5,716,000	5,410,920	2,743,257	2,667,663
Total Production (kWh)*	8,249,000	7,776,110	3,925,535	3,850,575
Capacity Factor*	29.59%		*Value calculated over the last 12 months	

B. Site Energy Production Graph September-2018



Monthly Report
September-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2018	Goldwind 2.5 Year Maintenance	~8	W1
November-2018	Goldwind 2.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
------	-------	-------------------	---------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Annual To Date
W1	100.00%	99.92%
W2	99.95%	99.95%
Avg	99.98%	99.94%
Downtime (hr)	This Month	Annual To Date
W1	6.15	134.90
W2	1.96	110.79
Total	8.11	245.69

G. Billed Data

Meter Reading (Date/Time)	9/28/2018 12:00 AM
Meter To Date Produced	20,772,846 kWh
Meter To Date Consumed	42,148 kWh
Last Reading Produced	20,338,499 kWh
Last Reading Consumed	40,870 kWh
Billed kWh	433,069 kWh
Next Meter Reading	10/28/2018 12:00 AM

H. Report Notes and Comments

*Change to P50 Expected Production due to Material Change in Circumstance.