




A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-18	990,000	679,703	238,340	226,535	214,828
Nov-18	1,123,000	-	-	-	-
Dec-18	1,153,000	-	-	-	-
Jan-19	1,306,000	-	-	-	-
Feb-19	1,137,000	-	-	-	-
Mar-19	1,134,000	-	-	-	-
Apr-19	1,176,000	-	-	-	-
May-19	927,000	-	-	-	-
Jun-19	634,000	-	-	-	-
Jul-19	527,000	-	-	-	-
Aug-19	449,000	-	-	-	-
Sep-19	610,000	-	-	-	-
Oct-19	990,000	-	-	-	-
Production 2017 (ytd) (kWh)	990,000	679,703	238,340	226,535	214,828
Total Production (kWh)*	11,166,000	0	0	0	0
Capacity Factor*	-	*Value calculated over the last 12 months			

B. Site Energy Production Graph

October-2018



Monthly Report
October-2018

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2018	Goldwind 500 Hour Maintenance	~8	WG 1
November-2018	Goldwind 500 Hour Maintenance	~8	WG 2
November-2018	Goldwind 500 Hour Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/ Unplanned	Duration (hrs)	Turbine
10/8-9/2018	System Safety Chain	Unplanned	36.92	WG2
10/8/2018	Owner Downtime	Unplanned	5.31	WG3
10/10-12/2018	Owner Downtime	Unplanned	51.49,7.91,52.26	WG1,2,3
10/16-17/2018	Owner Downtime	Unplanned	30.83,25.87	WG1,3
10/18/2018	Base Bolt Tentioning	Unplanned	7.82	WG2
10/20-21/2018	High Wind Event	Unplanned	16.44	WG1,2,3
10/22-23/2018	Convertor Fault	Unplanned	16.81	WG3
10/25-26/2018	Goldwind 500 Hour Maintenance	Planned	14.06	WG1
10/28-29/2018	High Wind Event	Unplanned	14.99	WG1,2,3
10/29-30/2018	Goldwind 500 Hour Maintenance	Planned	15.70	WG3
10/30/2018	Goldwind 500 Hour Maintenance	Planned	1.06	WG1
10/31/2018	Goldwind 500 Hour Maintenance	Planned	2.28	WG2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	100.00%
WG2	100.00%	100.00%
WG3	97.74%	97.74%
Avg	99.25%	99.25%

Downtime (hr)	This Month	Year To Date
WG1	137.01	137.01
WG2	86.36	86.36
WG3	148.55	148.55
Total	371.92	371.92

G. Billed Data**

Meter Reading (Date/Time)	12:00 AM
Meter To Date Produced	kWh
Meter To Date Consumed	kWh
Last Reading Produced	kWh
Last Reading Consumed	kWh
Billed kWh	0 kWh
Next Meter Reading	12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.

**Billing Start Date to be determined.