


A. Site Energy Production Summary**

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	W1	W2	W3	
Nov-17	1,123,000	466,686	-	-	-	**
Dec-17	1,153,000	852,755	-	-	-	**
Jan-18	1,306,000	1,214,611	405,820	399,594	409,197	
Feb-18	1,137,000	881,991	301,494	285,462	295,035	
Mar-18	1,134,000	1,184,135	407,384	386,300	390,451	
Apr-18	1,176,000	996,362	345,950	318,571	331,841	
May-18	927,000	759,639	251,931	248,291	259,417	
Jun-18	634,000	418,217	145,680	129,185	143,352	
Jul-18	527,000	333,148	111,051	106,463	115,634	
Aug-18	449,000	397,006	132,087	128,358	136,562	***
Sep-18	610,000	436,562	146,398	140,120	150,044	
Oct-18	990,000	742,865	258,249	240,231	244,385	
Nov-18	1,123,000	-	-	-	-	
Production 2018 (ytd) (kWh)	8,890,000	7,364,536	2,506,044	2,382,575	2,475,918	
Total Production (kWh)*	11,166,000	8,683,976	-	-	-	
Capacity Factor*	22.03%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

October-2018



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
November-2018	Goldwind 1 Year Maintenance	~15	W1
November-2018	Goldwind 1 Year Maintenance	~15	W2
November-2018	Goldwind 1 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/16/2018	Grid Fault	Unplanned	4.95	W1,2,3
10/17/2018	Grid Fault	Unplanned	4.58	W1,2,3
10/20-21/2018	Grid Frequency Stabilization	Unplanned	25.06	W1,2,3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.98%	99.82%
W2	99.97%	99.52%
W3	99.94%	99.85%
Avg	99.96%	99.73%

Downtime (hr)	This Month	Year To Date
W1	47.77	315.98
W2	47.81	298.22
W3	47.85	247.41
Total	143.43	861.61

G. Billed Data

Meter Reading (Date/Time)	10/20/2018 12:00 AM
Meter To Date Produced	8,225,646 kWh
Meter To Date Consumed	28,791 kWh
Last Reading Produced	7,544,378 kWh
Last Reading Consumed	27,134 kWh
Billed kWh	679,610 kWh
Next Meter Reading	11/20/2018 12:00 AM

H. Report Notes and Comments

*Dates changed to reflect Goldwind's projected maintenance schedule.
**Nov-17 and Dec-17 production data read from meter.
***August production data includes three days read from meter due to SCADA issue.