




A. Site Energy Production Summary

	Energy Production (kWh)		
	Site		
	P50 (Expected Production)	Actual Production	
Jan-18	450,000	146,791	**
Feb-18	473,000	335,605	
Mar-18	417,000	442,275	
Apr-18	494,000	391,503	
May-18	315,000	324,011	
Jun-18	220,000	202,020	
Jul-18	199,000	149,361	
Aug-18	209,000	149,747	
Sep-18	180,000	120,485	
Oct-18	337,000	377,866	
Nov-18	440,000	347,233	
Dec-18	532,000	384,067	
Jan-19	450,000	-	
Production 2018 (ytd) (kWh)	4,266,000	3,370,964	
Total Production (kWh)*	4,266,000	3,370,964	
Capacity Factor*	25.65%		*Value calculated over the last 12 months

B. Site Energy Production Graph

December-2018



Monthly Report
December-2018

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
January-2019	Goldwind 1 Year Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/5/2018	Paulding Putnam Elec. Coop. Maintenance	Unplanned	5.46	W1
12/31/2018	High Wind Event	Unplanned	6.15	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.83%
Downtime (hr)	This Month	Year To Date
W1	13.86	608.93

G. Billed Data

Meter Reading (Date/Time)	12/31/2018 12:00 AM
Meter To Date Produced	3,308,684 kWh
Meter To Date Consumed	21,445 kWh
Last Reading Produced	2,941,140 kWh
Last Reading Consumed	20,236 kWh
Billed kWh	366,334 kWh
Next Meter Reading	1/31/2019 12:00 AM

H. Report Notes and Comments

**Jan-18 production data read from meter (produced)