


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	V1	V2	
Sep-18	449,000	151,192	-	-	**
Oct-18	688,000	665,292	327,890	337,402	
Nov-18	804,000	481,743	247,418	234,325	
Dec-18	822,000	694,925	363,901	331,024	
Jan-19	924,000	965,472	479,398	486,074	
Feb-19	736,000	-	-	-	
Mar-19	794,000	-	-	-	
Apr-19	734,000	-	-	-	
May-19	574,000	-	-	-	
Jun-19	429,000	-	-	-	
Jul-19	357,000	-	-	-	
Aug-19	314,000	-	-	-	
Sep-19	449,000	-	-	-	
Production 2019 (ytd) (kWh)	924,000	965,472	479,398	486,074	
Total Production (kWh)*	-	-	-	-	
Capacity Factor*	-		*Value calculated over the last 12 months		

B. Site Energy Production Graph

January-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
April-19	Goldwind 6 Month Maintenance	~8	V1
April-19	Goldwind 6 Month Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/1/2019	High WindEvent	Unplanned	7.25	V1, V2
1/2/2019	Brake Maintenance	Unplanned	8.03	V1
1/11/2019	Goldwind Basement Maintenance	Planned	7.81	V1
1/11/2019	Goldwind Basement Maintenance	Planned	1.63	V2
1/15-16/2019	Icing Event	Unplanned	19.76	V1
1/15-16/2019	Icing Event	Unplanned	19.35	V2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	98.92%	98.92%
V2	100.00%	100.00%
Avg	99.46%	99.46%
Downtime (hr)	This Month	Year To Date
V1	42.85	42.85
V2	28.23	28.23
Total	71.08	71.08

G. Billed Data

Meter Reading (Date/Time)	1/31/2019 12:00 AM
Meter To Date Produced	2,873,604 kWh
Meter To Date Consumed	6,227 kWh
Last Reading Produced	1,929,818 kWh
Last Reading Consumed	5,037 kWh
Billed kWh	942,596 kWh
Next Meter Reading	2/28/2019 12:00 AM

H. Report Notes and Comments

*Maintenance Events updated to reflect Goldwind's estimated Maintenance Schedule.
**Sep-18 production data read from meter. Capacity factor to be included once full year of data is available.