


A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-18	990,000	679,703	238,340	226,535	214,828
Nov-18	1,123,000	816,424	287,961	268,275	260,188
Dec-18	1,153,000	1,053,069	363,815	347,442	341,812
Jan-19	1,306,000	952,287	325,224	314,810	312,253
Feb-19	1,137,000	-	-	-	-
Mar-19	1,134,000	-	-	-	-
Apr-19	1,176,000	-	-	-	-
May-19	927,000	-	-	-	-
Jun-19	634,000	-	-	-	-
Jul-19	527,000	-	-	-	-
Aug-19	449,000	-	-	-	-
Sep-19	610,000	-	-	-	-
Oct-19	990,000	-	-	-	-
Production 2019 (ytd) (kWh)	1,306,000	952,287	325,224	314,810	312,253
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	-		*Value calculated over the last 12 months		

B. Site Energy Production Graph

January-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
April-2019	Goldwind 6 Month Maintenance	~8	WG 1
April-2019	Goldwind 6 Month Maintenance	~8	WG 2
April-2019	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/3/2019	Brake Maintenance	Unplanned	6.41	WG 1
1/4-5/2019	Noise Inspection	Unplanned	26.31	WG 1
1/4-5/2019	Noise Inspection	Unplanned	22.37	WG 2
1/4-5/2019	Noise Inspection	Unplanned	16.06	WG 3
1/15-16/2019	Icing Event	Unplanned	33.99	WG 1
1/15-16/2019	Icing Event	Unplanned	33.75	WG 2
1/15-16/2019	Icing Event	Unplanned	33.17	WG 3
1/19-22/2019	Icing Event	Unplanned	80.16	WG 1
1/19-22/2019	Icing Event	Unplanned	78.79	WG 2
1/19-22/2019	Icing Event	Unplanned	76.50	WG 3
1/24-25/2019	Icing Event	Unplanned	38.77	WG 1
1/24-25/2019	Icing Event	Unplanned	38.95	WG 2
1/24-25/2019	Icing Event	Unplanned	39.01	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	99.14%	99.14%
WG2	100.00%	100.00%
WG3	100.00%	100.00%
Avg	99.71%	99.71%

Downtime (hr)	This Month	Year To Date
WG1	185.64	185.64
WG2	173.86	173.86
WG3	164.74	164.74
Total	524.24	524.24

G. Billed Data

Meter Reading (Date/Time)	1/28/2019 12:00 AM
Meter To Date Produced	3,132,051 kWh
Meter To Date Consumed	15,295 kWh
Last Reading Produced	2,269,540 kWh
Last Reading Consumed	9,085 kWh
Billed kWh	856,301 kWh
Next Meter Reading	2/28/2019 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.