




A. Site Energy Production Summary

Energy Production (kWh)					
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Feb-18	1,157,019	1,303,000	447,860	426,380	428,760
Mar-18	1,242,761	1,576,970	530,020	505,480	541,470
Apr-18	1,447,248	1,316,810	462,450	405,270	449,090
May-18	1,010,966	1,077,570	344,730	377,970	354,870
Jun-18	668,411	686,130	223,300	224,540	238,290
Jul-18	638,097	499,960	165,840	165,390	168,730
Aug-18	577,992	610,690	217,500	193,470	199,720
Sep-18	631,697	754,220	249,590	254,010	250,620
Oct-18	1,003,602	1,199,060	420,610	355,340	423,110
Nov-18	1,395,914	1,126,610	386,320	352,100	388,190
Dec-18	1,278,858	1,203,370	406,960	390,900	405,510
Jan-19	1,332,437	1,549,490	530,840	514,790	503,860
Feb-19	1,157,019	1,189,460	406,280	396,000	387,180
Production 2019 (ytd) (kWh)	2,489,456	2,738,950	937,120	910,790	891,040
Total Production (kWh)*	12,384,999	12,790,340	4,344,440	4,135,260	4,310,640
Capacity Factor*	32.45%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

February-2019



Monthly Report
February-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
March-2019	Goldwind 6.5 Year Maintenance	~8	WTG A
March-2019	Goldwind 6.5 Year Maintenance	~8	WTG B
March-2019	Goldwind 6.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events - February 2019

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
2/1/2019	Goldwind 6.5 Year Maintenance	Planned	4.77	WTG A
2/12/2019	Icing Event	Unplanned	10.82	WTG A,WTG B
2/12/2019	Icing Event	Unplanned	10.81	WTG C
2/13/2019	Converter Inductor Error	Unplanned	4.38	WTG C
2/24/2019	High Wind Event	Unplanned	21.00	WTG A,WTG B,WTG C
2/25/2019	High Wind Event	Unplanned	5.54	WTG A,WTG B,WTG C

F. Turbine Availability & Downtime

Availability (%)	This Month	Year to Date
WTG A	100.00%	100.00%
WTG B	100.00%	99.46%
WTG C	99.35%	98.07%
Avg	99.78%	99.18%

Downtime (hr)	This Month	Year to Date
WTG A	42.82	61.42
WTG B	38.05	68.37
WTG C	43.30	97.73
Total	124.17	227.52

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2019 Annual
WTG A	14.41	14.30
WTG B	14.47	14.35
WTG C	15.08	15.03
Estimated	17.02	13.39

Capacity Factor (%)	This Month	2019 Annual
WTG A	40.31%	44.12%
WTG B	39.29%	42.88%
WTG C	38.41%	41.95%
Low Estimate	29.98%	42.98%

H. Report Notes and Comments

*Goldwind 6.5 Year Maintenance to continue in March.