




A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Feb-18	914,000	718,724	362,629	356,095
Mar-18	808,000	853,902	432,831	421,071
Apr-18	955,000	748,389	381,330	367,059
May-18	607,000	594,897	296,616	298,281
Jun-18	425,000	410,074	205,521	204,553
Jul-18	385,000	278,804	145,255	133,549
Aug-18	404,000	365,718	185,127	180,591
Sep-18	346,000	399,326	202,515	196,811
Oct-18	649,000	709,011	359,965	349,046
Nov-18	846,000	616,294	307,095	309,199
Dec-18	1,022,000	737,042	376,399	360,643
Jan-19	867,000	942,829	486,578	456,251
Feb-19	908,000	707,729	356,127	351,602
Production 2019 (ytd) (kWh)	1,775,000	1,650,558	842,705	807,853
Total Production (kWh)*	8,222,000	7,364,015	3,735,359	3,628,656
Capacity Factor*	28.02%		*Value calculated over the last 12 months	

B. Site Energy Production Graph February-2019



Monthly Report
February-2019

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
May-2019	Goldwind 3.5 Year Maintenance	~8	W1
May-2019	Goldwind 3.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
2/11/2019	Icing Event	Unplanned	15.88	W1,W2
2/12/2019	Icing Event	Unplanned	13.80	W1,W2
2/18/2019	Icing Event	Unplanned	9.83	W1
2/18/2019	Icing Event	Unplanned	8.21	W2
2/19/2019	Icing Event	Unplanned	5.76	W1
2/19/2019	Icing Event	Unplanned	5.27	W2
2/20/2019	Icing Event	Unplanned	4.37	W1
2/20/2019	Icing Event	Unplanned	4.38	W2
2/24/2019	High Wind Event	Unplanned	20.82	W1,W2
2/25/2019	High Wind Event	Unplanned	5.79	W1,W2

F. Turbine Availability & Downtime

Availability	This Month	Annual To Date
W1	100.00%	99.04%
W2	100.00%	97.99%
Avg	100.00%	98.52%
Downtime (hr)	This Month	Annual To Date
W1	76.48	124.85
W2	75.12	135.59
Total	151.60	260.44

G. Billed Data

Meter Reading (Date/Time)	3/1/2019 12:00 AM
Meter To Date Produced	24,477,966 kWh
Meter To Date Consumed	49,996 kWh
Last Reading Produced	23,571,131 kWh
Last Reading Consumed	47,850 kWh
Billed kWh	904,689 kWh
Next Meter Reading	4/29/2018 12:00 AM

H. Report Notes and Comments

*Change to P50 Expected Production due to Material Change in Circumstance.