


A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-18	990,000	679,703	238,340	226,535	214,828
Nov-18	1,123,000	816,424	287,961	268,275	260,188
Dec-18	1,153,000	1,053,069	363,815	347,442	341,812
Jan-19	1,306,000	952,287	325,224	314,810	312,253
Feb-19	1,137,000	935,828	324,947	304,407	306,474
Mar-19	1,134,000	-	-	-	-
Apr-19	1,176,000	-	-	-	-
May-19	927,000	-	-	-	-
Jun-19	634,000	-	-	-	-
Jul-19	527,000	-	-	-	-
Aug-19	449,000	-	-	-	-
Sep-19	610,000	-	-	-	-
Oct-19	990,000	-	-	-	-
Production 2019 (ytd) (kWh)	2,443,000	1,888,115	650,171	619,217	618,727
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	-	*Value calculated over the last 12 months			

B. Site Energy Production Graph

February-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
April-2019	Goldwind 6 Month Maintenance	~8	WG 1
April-2019	Goldwind 6 Month Maintenance	~8	WG 2
April-2019	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/12/2019	Icing Event	Unplanned	11.13	WG 1,2,3
2/18/2019	Icing Event	Unplanned	4.75	WG 1,3
2/18/2019	Icing Event	Unplanned	8.22	WG 2
2/18/2019	Icing Event	Unplanned	5.41	WG 1,2
2/19/2019	Icing Event	Unplanned	5.44	WG 3
2/22/2019	Anchor Bolt Painting	Unplanned	7.87	WG 1,2,3
2/24/2019	High Wind Event	Unplanned	21.08	WG 1,2,3
2/25/2019	High Wind Event	Unplanned	5.53	WG 1,2,3
2/28/2019	Low Hydraulic Oil Level	Unplanned	20.88	WG 2

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WG1	100.00%	99.55%
WG2	96.89%	98.53%
WG3	99.95%	99.97%
Avg	98.95%	99.35%

Downtime (hr)	This Month	Year To Date
WG1	61.14	246.78
WG2	85.50	259.36
WG3	61.53	226.27
Total	208.17	732.41

G. Billed Data

Meter Reading (Date/Time)	3/1/2019 12:00 AM
Meter To Date Produced	4,257,578 kWh
Meter To Date Consumed	19,288 kWh
Last Reading Produced	3,132,051 kWh
Last Reading Consumed	15,295 kWh
Billed kWh	1,121,534 kWh
Next Meter Reading	3/29/2019 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.

**Goldwind Availability pending further review.