


A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	V1	V2		
Sep-18	449,000	151,192	-	-	**	
Oct-18	688,000	665,292	327,890	337,402		
Nov-18	804,000	481,743	247,418	234,325		
Dec-18	822,000	694,925	363,901	331,024		
Jan-19	924,000	965,472	479,398	486,074		
Feb-19	736,000	656,163	327,762	328,401		
Mar-19	794,000	838,578	420,238	418,340		
Apr-19	734,000	-	-	-		
May-19	574,000	-	-	-		
Jun-19	429,000	-	-	-		
Jul-19	357,000	-	-	-		
Aug-19	314,000	-	-	-		
Sep-19	449,000	-	-	-		
Production 2019 (ytd) (kWh)	2,454,000	2,460,213	1,227,398	1,232,815		
Total Production (kWh)*	-	-	-	-		
Capacity Factor*	-		*Value calculated over the last 12 months			

B. Site Energy Production Graph

March-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-19	Goldwind 6 Month Maintenance	~8	V1
April-19	Goldwind 6 Month Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/ Unplanned	Duration (hrs)	Turbine
------	-------	--------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	99.61%
V2	100.00%	100.00%
Avg	100.00%	99.80%
Downtime (hr)	This Month	Year To Date
V1	0.20	142.98
V2		116.75
Total	0.20	259.73

G. Billed Data

Meter Reading (Date/Time)	4/1/2019 12:00 AM
Meter To Date Produced	4,351,776 kWh
Meter To Date Consumed	9,332 kWh
Last Reading Produced	3,532,967 kWh
Last Reading Consumed	7,897 kWh
Billed kWh	817,374 kWh
Next Meter Reading	5/1/2019 12:00 AM

H. Report Notes and Comments

**Sep-18 production data read from meter. Capacity factor to be included once full year of data is available.