


A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	V1	V2		
Sep-18	449,000	151,192	-	-	**	
Oct-18	688,000	665,292	327,890	337,402		
Nov-18	804,000	481,743	247,418	234,325		
Dec-18	822,000	694,925	363,901	331,024		
Jan-19	924,000	965,472	479,398	486,074		
Feb-19	736,000	656,163	327,762	328,401		
Mar-19	794,000	838,578	420,238	418,340		
Apr-19	734,000	855,698	425,093	430,605		
May-19	574,000	-	-	-		
Jun-19	429,000	-	-	-		
Jul-19	357,000	-	-	-		
Aug-19	314,000	-	-	-		
Sep-19	449,000	-	-	-		
Production 2019 (ytd) (kWh)	3,188,000	3,315,911	1,652,491	1,663,420		
Total Production (kWh)*	-	-	-	-		
Capacity Factor*	-		*Value calculated over the last 12 months			

B. Site Energy Production Graph

April-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
May-19	Goldwind 6 Month Maintenance	~8	V1
May-19	Goldwind 6 Month Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/2/2019	Owner/Operator Shutdown	Unplanned	6.38	V1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	99.71%
V2	100.00%	100.00%
Avg	100.00%	99.85%
Downtime (hr)	This Month	Year To Date
V1	6.63	149.61
V2	0.25	117.00
Total	6.88	266.61

G. Billed Data

Meter Reading (Date/Time)	5/1/2019 12:00 AM
Meter To Date Produced	5,187,581 kWh
Meter To Date Consumed	10,294 kWh
Last Reading Produced	4,351,776 kWh
Last Reading Consumed	9,332 kWh
Billed kWh	834,843 kWh
Next Meter Reading	6/1/2019 12:00 AM

H. Report Notes and Comments

*Goldwind Maintenance moved to May.
**Sep-18 production data read from meter. Capacity factor to be included once full year of data is available.