


### A. Site Energy Production Summary

|                             | Energy Production (kWh)   |                   |
|-----------------------------|---------------------------|-------------------|
|                             | Site                      |                   |
|                             | P50 (Expected Production) | Actual Production |
| Apr-18                      | 494,000                   | 391,503           |
| May-18                      | 315,000                   | 324,011           |
| Jun-18                      | 220,000                   | 202,020           |
| Jul-18                      | 199,000                   | 149,361           |
| Aug-18                      | 209,000                   | 149,747           |
| Sep-18                      | 180,000                   | 120,485           |
| Oct-18                      | 337,000                   | 377,866           |
| Nov-18                      | 440,000                   | 347,233           |
| Dec-18                      | 532,000                   | 384,067           |
| Jan-19                      | 450,000                   | 424,745           |
| Feb-19                      | 473,000                   | 354,625           |
| Mar-19                      | 417,000                   | 450,944           |
| Apr-19                      | 494,000                   | 450,366           |
| Production 2019 (ytd) (kWh) | 1,834,000                 | 1,680,680         |
| Total Production (kWh)*     | 4,266,000                 | 3,735,470         |
| Capacity Factor*            | 28.43%                    |                   |

\*Value calculated over last 12 months

### B. Site Energy Production Graph

April-2019



## Monthly Report

### April-2019

### C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

### D. Planned Maintenance Events\*

| Date           | Event                         | Duration (hr) | Turbine |
|----------------|-------------------------------|---------------|---------|
| September-2019 | Goldwind 1.5 Year Maintenance | ~8            | W1      |

### E. Actual Maintenance Events

| Date | Event | Planned/Unplanned | Duration (hrs) | Turbine |
|------|-------|-------------------|----------------|---------|
|------|-------|-------------------|----------------|---------|

### F. Turbine Availability & Downtime

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| W1           | 100.00%    | 98.99%       |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| W1            |            | 213.61       |

### G. Billed Data

|                           |                   |
|---------------------------|-------------------|
| Meter Reading (Date/Time) | 5/1/2019 12:00 AM |
| Meter To Date Produced    | 4,978,480 kWh     |
| Meter To Date Consumed    | 27,290 kWh        |
| Last Reading Produced     | 4,534,108 kWh     |
| Last Reading Consumed     | 26,485 kWh        |
| Billed kWh                | 443,567 kWh       |
| Next Meter Reading        | 6/1/2019 12:00 AM |

### H. Report Notes and Comments