



WHIRLPOOL CORPORATION

Greenville Wind Farm, Greenville OH




A. Site Energy Production Summary*

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-18	1,051,000	679,703	238,340	226,535	214,828
Nov-18	1,224,000	816,424	287,961	268,275	260,188
Dec-18	1,217,000	1,053,069	363,815	347,442	341,812
Jan-19	1,343,000	952,287	325,224	314,810	312,253
Feb-19	1,133,000	935,828	324,947	304,407	306,474
Mar-19	1,312,000	1,099,016	403,803	310,433	384,780
Apr-19	1,272,000	1,210,371	406,808	400,071	403,492
May-19	974,000	805,247	272,374	265,063	267,810
Jun-19	714,000	-	-	-	-
Jul-19	566,000	-	-	-	-
Aug-19	514,000	-	-	-	-
Sep-19	716,000	-	-	-	-
Oct-19	1,051,000	-	-	-	-
Production 2019 (ytd) (kWh)	6,034,000	5,002,749	1,733,156	1,594,784	1,674,809
Total Production (kWh)*	-	-	-	-	-
Capacity Factor*	-	*Value calculated over the last 12 months			

B. Site Energy Production Graph

May-2019



Monthly Report May-2019

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
June-2019	Goldwind 6 Month Maintenance	~8	WG 1
June-2019	Goldwind 6 Month Maintenance	~8	WG 2
June-2019	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/20/2019	Owner/Operator Infrastructure Maintenance	Unplanned	8.26	WG1, WG2, WG3
5/21/2019	Owner/Operator Infrastructure Maintenance	Unplanned	4.52	WG2
5/28/2019	High Wind Event	Unplanned	5.17	WG1, WG2, WG3
5/30/2019	Owner/Operator Punchlist Completion	Unplanned	4.73	WG3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	99.82%
WG2	100.00%	99.42%
WG3	100.00%	99.99%
Avg	100.00%	99.75%

Downtime (hr)	This Month	Year To Date
WG1	21.26	281.97
WG2	24.30	518.18
WG3	26.93	265.15
Total	72.49	1065.30

G. Billed Data

Meter Reading (Date/Time)	5/29/2019 12:00 AM
Meter To Date Produced	7,290,093 kWh
Meter To Date Consumed	26,599 kWh
Last Reading Produced	6,470,459 kWh
Last Reading Consumed	23,879 kWh
Billed kWh	816,914 kWh
Next Meter Reading	6/29/2019 12:00 AM

H. Report Notes and Comments

*Capacity factor to be included once full year of data is available.

**Goldwind Maintenance moved to June.