




Monthly Report
June-2019



A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jun-18	425,000	410,074	205,521	204,553
Jul-18	385,000	278,804	145,255	133,549
Aug-18	404,000	365,718	185,127	180,591
Sep-18	346,000	399,326	202,515	196,811
Oct-18	649,000	709,011	359,965	349,046
Nov-18	846,000	616,294	307,095	309,199
Dec-18	1,022,000	737,042	376,399	360,643
Jan-19	867,000	942,829	486,578	456,251
Feb-19	908,000	707,729	356,127	351,602
Mar-19	803,000	848,505	435,774	412,731
Apr-19	949,000	852,957	427,080	425,877
May-19	603,000	615,463	306,237	309,226
Jun-19	422,000	474,817	240,372	234,445
Production 2019 (ytd) (kWh)	4,552,000	4,442,300	2,252,168	2,190,132
Total Production (kWh)*	8,204,000	7,548,495	3,828,524	3,719,971
Capacity Factor*	28.72%		*Value calculated over the last 12 months	

B. Site Energy Production Graph
June-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
December-2019	Goldwind 4 Year Maintenance	~15	W1
December-2019	Goldwind 4 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
6/3/2019	Goldwind 3.5 Year Maintenance	Planned	5.52	W2
6/11/2019	Goldwind 3.5 Year Maintenance	Planned	2.33	W1, W2

F. Turbine Availability & Downtime

Availability	This Month	Annual To Date
W1	100.00%	99.67%
W2	100.00%	99.34%
Avg	100.00%	99.50%
Downtime (hr)	This Month	Annual To Date
W1	10.63	197.40
W2	16.19	197.07
Total	26.82	394.47

G. Billed Data

Meter Reading (Date/Time)	6/29/2019 12:00 AM
Meter To Date Produced	27,211,429 kWh
Meter To Date Consumed	54,297 kWh
Last Reading Produced	26,745,169 kWh
Last Reading Consumed	52,873 kWh
Billed kWh	464,836 kWh
Next Meter Reading	7/29/2019 12:00 AM

H. Report Notes and Comments

*Change to P50 Expected Production due to Material Change in Circumstance.