




Monthly Report
July-2019



A. Site Energy Production Summary*

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jul-18	385,000	278,804	145,255	133,549
Aug-18	404,000	365,718	185,127	180,591
Sep-18	346,000	399,326	202,515	196,811
Oct-18	649,000	709,011	359,965	349,046
Nov-18	846,000	616,294	307,095	309,199
Dec-18	1,022,000	737,042	376,399	360,643
Jan-19	867,000	942,829	486,578	456,251
Feb-19	908,000	707,729	356,127	351,602
Mar-19	803,000	848,505	435,774	412,731
Apr-19	949,000	852,957	427,080	425,877
May-19	603,000	615,463	306,237	309,226
Jun-19	422,000	474,817	240,372	234,445
Jul-19	383,000	338,373	171,861	166,512
Production 2019 (ytd) (kWh)	4,935,000	4,780,673	2,424,029	2,356,644
Total Production (kWh)*	8,202,000	7,608,064	3,855,130	3,752,934
Capacity Factor*	28.95%		*Value calculated over the last 12 months	

B. Site Energy Production Graph July-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events**

Date	Event	Duration (hr)	Turbine
December-2019	Goldwind 4 Year Maintenance	~15	W1
December-2019	Goldwind 4 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hr)	Turbine
------	-------	-------------------	---------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Annual To Date
W1	99.97%	99.71%
W2	100.00%	99.44%
Avg	99.99%	99.57%
Downtime (hr)	This Month	Annual To Date
W1	4.42	201.82
W2	0.97	198.04
Total	5.39	399.86

G. Billed Data

Meter Reading (Date/Time)	7/29/2019 12:00 AM
Meter To Date Produced	27,534,407 kWh
Meter To Date Consumed	56,076 kWh
Last Reading Produced	27,211,429 kWh
Last Reading Consumed	54,297 kWh
Billed kWh	321,200 kWh
Next Meter Reading	8/29/2019 12:00 AM

H. Report Notes and Comments

*Change to P50 Expected Production due to Material Change in Circumstance.