


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Jul-18	199,000	149,361
Aug-18	209,000	149,747
Sep-18	180,000	120,485
Oct-18	337,000	377,866
Nov-18	440,000	347,233
Dec-18	532,000	384,067
Jan-19	450,000	424,745
Feb-19	473,000	354,625
Mar-19	417,000	450,944
Apr-19	494,000	450,366
May-19	315,000	335,596
Jun-19	220,000	276,978
Jul-19	199,000	166,408
Production 2019 (ytd) (kWh)	2,568,000	2,459,662
Total Production (kWh)*	4,266,000	3,839,060
Capacity Factor*	29.22% *Value calculated over last 12 months	

B. Site Energy Production Graph

July-2019



Monthly Report July-2019

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
September-2019	Goldwind 1.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.97%	99.42%
Downtime (hr)	This Month	Year To Date
W1	4.90	246.55

G. Billed Data

Meter Reading (Date/Time)	8/1/219 12:00 AM
Meter To Date Produced	5,746,039 kWh
Meter To Date Consumed	32,406 kWh
Last Reading Produced	5,582,455 kWh
Last Reading Consumed	29,973 kWh
Billed kWh	161,151 kWh
Next Meter Reading	9/1/2019 12:00 AM

H. Report Notes and Comments