


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Aug-18	209,000	149,747
Sep-18	180,000	120,485
Oct-18	337,000	377,866
Nov-18	440,000	347,233
Dec-18	532,000	384,067
Jan-19	450,000	424,745
Feb-19	473,000	354,625
Mar-19	417,000	450,944
Apr-19	494,000	450,366
May-19	315,000	335,596
Jun-19	220,000	276,978
Jul-19	199,000	166,408
Aug-19	209,000	188,300
Production 2019 (ytd) (kWh)	2,777,000	2,647,962
Total Production (kWh)*	4,266,000	3,877,613
Capacity Factor*	29.51%	

*Value calculated over last 12 months

B. Site Energy Production Graph

August-2019



Monthly Report

August-2019

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
September-2019	Goldwind 1.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.49%

Downtime (hr)	This Month	Year To Date
W1	2.50	249.05

G. Billed Data

Meter Reading (Date/Time)	9/1/2019 12:00 AM
Meter To Date Produced	5,931,169 kWh
Meter To Date Consumed	34,065 kWh
Last Reading Produced	5,746,039 kWh
Last Reading Consumed	32,406 kWh
Billed kWh	183,471 kWh
Next Meter Reading	10/1/2019 12:00 AM

H. Report Notes and Comments