


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Oct-18	1,051,000	679,703	238,340	226,535	214,828
Nov-18	1,224,000	816,424	287,961	268,275	260,188
Dec-18	1,217,000	1,053,069	363,815	347,442	341,812
Jan-19	1,343,000	952,287	325,224	314,810	312,253
Feb-19	1,133,000	935,828	324,947	304,407	306,474
Mar-19	1,312,000	1,099,016	403,803	310,433	384,780
Apr-19	1,272,000	1,210,371	406,808	400,071	403,492
May-19	974,000	805,247	272,374	265,063	267,810
Jun-19	714,000	750,094	254,695	247,674	247,725
Jul-19	566,000	437,042	130,830	155,812	150,400
Aug-19	514,000	482,340	171,490	156,018	154,832
Sep-19	716,000	597,745	203,475	201,926	192,344
Oct-19	1,051,000	1,033,402	351,806	342,691	338,905
Production 2019 (ytd) (kWh)	9,595,000	8,303,372	2,845,452	2,698,905	2,759,015
Total Production (kWh)*	12,036,000	10,172,865	3,497,228	3,314,622	3,361,015
Capacity Factor*	25.81%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

October-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
November-2019	Goldwind 6 Month Maintenance	~8	WG 1
November-2019	Goldwind 6 Month Maintenance	~8	WG 2
November-2019	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/6/2019	Owner/Operator Maintenance	Unplanned	6.26	WG 2
10/7/2019	Owner/Operator Maintenance	Unplanned	4.73	WG 1

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WG1	100.00%	97.61%
WG2	100.00%	99.66%
WG3	99.89%	99.80%
Avg	99.96%	99.02%

Downtime (hr)	This Month	Year To Date
WG1	8.28	489.19
WG2	10.12	558.67
WG3	5.14	316.66
Total	23.54	1364.52

G. Billed Data

Meter Reading (Date/Time)	10/29/2019 12:00 AM
Meter To Date Produced	10,522,138 kWh
Meter To Date Consumed	43,447 kWh
Last Reading Produced	9,544,450 kWh
Last Reading Consumed	41,416 kWh
Billed kWh	975,656 kWh
Next Meter Reading	11/29/2019 12:00 AM

H. Report Notes and Comments

*Goldwind Maintenance moved to November.

**Goldwind Availability and Downtime under dispute.