


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Nov-18	1,224,000	816,424	287,961	268,275	260,188
Dec-18	1,217,000	1,053,069	363,815	347,442	341,812
Jan-19	1,343,000	952,287	325,224	314,810	312,253
Feb-19	1,133,000	935,828	324,947	304,407	306,474
Mar-19	1,312,000	1,099,016	403,803	310,433	384,780
Apr-19	1,272,000	1,210,371	406,808	400,071	403,492
May-19	974,000	805,247	272,374	265,063	267,810
Jun-19	714,000	750,094	254,695	247,674	247,725
Jul-19	566,000	437,042	130,830	155,812	150,400
Aug-19	514,000	482,340	171,490	156,018	154,832
Sep-19	716,000	597,745	203,475	201,926	192,344
Oct-19	1,051,000	1,033,402	351,806	342,691	338,905
Nov-19	1,224,000	869,845	297,447	287,622	284,776
Production 2019 (ytd) (kWh)	10,819,000	9,173,217	3,142,899	2,986,527	3,043,791
Total Production (kWh)*	12,036,000	10,226,286	3,506,714	3,333,969	3,385,603
Capacity Factor*	25.94%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

November-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
December-2019	Goldwind 6 Month Maintenance	~8	WG 1
December-2019	Goldwind 6 Month Maintenance	~8	WG 2
December-2019	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/11-12/2019	Icing Event	Unplanned	23.08	WG1
11/11-12/2019	Icing Event	Unplanned	23.13	WG2
11/11-12/2019	Icing Event	Unplanned	22.81	WG3
11/27/2019	High Wind Event	Unplanned	10.92	WG1, 2, 3

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WG1	100.00%	97.83%
WG2	100.00%	99.69%
WG3	99.94%	99.81%
Avg	99.98%	99.11%

Downtime (hr)	This Month	Year To Date
WG1	34.00	523.19
WG2	34.05	592.72
WG3	34.70	351.36
Total	102.75	1467.27

G. Billed Data

Meter Reading (Date/Time)	11/29/2019 12:00 AM
Meter To Date Produced	11,429,309 kWh
Meter To Date Consumed	46,954 kWh
Last Reading Produced	10,522,138 kWh
Last Reading Consumed	43,447 kWh
Billed kWh	903,664 kWh
Next Meter Reading	12/29/2019 12:00 AM

H. Report Notes and Comments

*Goldwind Maintenance moved to December.

**Goldwind Availability and Downtime under dispute.