


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Dec-18	1,153,000	990,824	341,399	318,787	330,638
Jan-19	1,306,000	1,228,632	427,801	398,420	402,411
Feb-19	1,137,000	898,559	307,088	293,895	297,576
Mar-19	1,134,000	1,123,196	385,735	362,764	374,697
Apr-19	1,176,000	1,017,622	347,943	331,201	338,478
May-19	927,000	753,487	261,344	247,282	244,861
Jun-19	634,000	653,072	224,916	205,888	222,268
Jul-19	527,000	357,677	119,328	116,242	122,107
Aug-19	449,000	423,670	145,657	134,069	143,944
Sep-19	610,000	414,660	141,275	131,797	141,588
Oct-19	990,000	916,038	308,623	294,939	312,476
Nov-19	1,123,000	846,849	291,098	273,259	282,492
Dec-19	1,153,000	1,139,609	398,017	365,419	376,173
Production 2019 (ytd) (kWh)	11,166,000	9,773,071	3,358,825	3,155,175	3,259,071
Total Production (kWh)*	11,166,000	9,773,071	3,358,825	3,155,175	3,259,071
Capacity Factor*	24.79%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

December-2019



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
January-2020	Goldwind 2 Year Maintenance	~15	W1
January-2020	Goldwind 2 Year Maintenance	~15	W2
January-2020	Goldwind 2 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/31/2019	Icing Event	Unplanned	4.38	W1
12/31/2019	Icing Event	Unplanned	4.43	W2
12/31/2019	Icing Event	Unplanned	4.89	W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.97%	99.86%
W2	99.94%	99.62%
W3	99.97%	99.59%
Avg	99.96%	99.69%

Downtime (hr)	This Month	Year To Date
W1	5.03	198.51
W2	5.24	230.36
W3	5.52	293.50
Total	15.79	722.37

G. Billed Data

Meter Reading (Date/Time)	12/21/2019 12:00 AM
Meter To Date Produced	19,353,475 kWh
Meter To Date Consumed	58,643 kWh
Last Reading Produced	18,247,757 kWh
Last Reading Consumed	57,110 kWh
Billed kWh	1,104,185 kWh
Next Meter Reading	1/21/2020 12:00 AM

H. Report Notes and Comments

*Goldwind 2 Year Maintenance to continue in January.