




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Feb-19	1,157,019	1,189,460	406,280	396,000	387,180
Mar-19	1,242,761	1,352,210	484,800	453,230	414,180
Apr-19	1,447,248	1,456,800	503,290	479,380	474,130
May-19	1,010,966	1,102,180	380,120	364,910	357,150
Jun-19	668,411	934,460	320,720	307,820	305,920
Jul-19	638,097	575,390	191,700	191,910	191,780
Aug-19	577,992	634,650	218,690	210,230	205,730
Sep-19	631,697	732,500	253,580	232,050	246,870
Oct-19	1,003,602	1,248,994	421,770	423,766	403,458
Nov-19	1,395,914	1,124,700	383,460	368,940	372,300
Dec-19	1,278,858	1,370,840	492,520	451,610	426,710
Jan-20	1,332,437	1,346,410	458,880	440,070	447,460
Feb-20	1,157,019	1,226,310	419,290	406,120	400,900
Production 2020 (ytd) (kWh)	2,489,456	2,572,720	878,170	846,190	848,360
Total Production (kWh)*	12,384,999	13,105,444	4,528,820	4,330,036	4,246,588
Capacity Factor*	33.15%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

February-2020



Monthly Report
February-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2020	Goldwind 7.5 Year Maintenance	~8	WTG A
March-2020	Goldwind 7.5 Year Maintenance	~8	WTG B
March-2020	Goldwind 7.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
2/5-6/2020	Icing Event	Unplanned	20.20	WTG B
2/5-8/2020	Icing Event	Unplanned	62.43	WTG C
2/6/2020	Icing Event	Unplanned	12.01	WTG A

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	100.00%
WTG C	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG A	13.87	18.34
WTG B	22.06	28.57
WTG C	67.39	74.11
Total	103.32	121.02

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2020 Annual
WTG A	12.92	12.79
WTG B	12.79	12.72
WTG C	13.47	13.44
Estimated	17.02	13.39

Capacity Factor (%)	This Month	2020 Annual
WTG A	40.16%	40.66%
WTG B	38.90%	39.18%
WTG C	38.40%	39.28%
Low Estimate	29.98%	28.72%

H. Report Notes and Comments

*WTG C total production includes estimated production for April 1-7 2019 due to meter malfunction.