


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Mar-19	794,000	838,578	420,238	418,340
Apr-19	734,000	855,698	425,093	430,605
May-19	574,000	605,674	299,620	306,054
Jun-19	429,000	479,262	235,381	243,881
Jul-19	357,000	307,376	145,001	162,375
Aug-19	314,000	369,367	181,572	187,795
Sep-19	449,000	392,366	197,834	194,532
Oct-19	688,000	676,972	338,413	338,559
Nov-19	804,000	631,219	315,003	316,216
Dec-19	822,000	904,108	456,015	448,093
Jan-20	924,000	772,641	385,505	387,136
Feb-20	736,000	640,848	302,976	337,872
Mar-20	794,000	758,754	383,099	375,655
Production 2020 (ytd) (kWh)	2,454,000	2,172,243	1,071,580	1,100,663
Total Production (kWh)*	7,625,000	7,394,285	3,665,512	3,728,773
Capacity Factor*	28.06%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

March-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
April-20	Goldwind 6 Month Maintenance	~8	V1
April-20	Goldwind 6 Month Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/2/2020	Owner/Operator Maintenance	Unplanned	15.24	V2
3/3/2020	Owner/Operator Maintenance	Unplanned	13.25	V2
3/4/2020	Owner/Operator Maintenance	Unplanned	4.19	V1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	100.00%
V2	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
V1	5.49	128.97
V2	29.57	129.64
Total	35.06	258.61

G. Billed Data

Meter Reading (Date/Time)	4/1/2020 12:00 AM
Meter To Date Produced	11,571,884 kWh
Meter To Date Consumed	28,138 kWh
Last Reading Produced	10,829,647 kWh
Last Reading Consumed	26,413 kWh
Billed kWh	740,513 kWh
Next Meter Reading	5/1/2020 12:00 AM

H. Report Notes and Comments

*Goldwind Maintenance moved to April.