


A. Site Energy Production Summary

Energy Production (kWh)					
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Mar-19	1,312,000	1,099,016	403,803	310,433	384,780
Apr-19	1,272,000	1,210,371	406,808	400,071	403,492
May-19	974,000	805,247	272,374	265,063	267,810
Jun-19	714,000	750,094	254,695	247,674	247,725
Jul-19	566,000	437,042	130,830	155,812	150,400
Aug-19	514,000	482,340	171,490	156,018	154,832
Sep-19	716,000	597,745	203,475	201,926	192,344
Oct-19	1,051,000	1,033,402	351,806	342,691	338,905
Nov-19	1,224,000	869,845	297,447	287,622	284,776
Dec-19	1,217,000	1,216,234	461,480	437,079	317,675
Jan-20	1,343,000	966,360	362,196	344,267	259,897
Feb-20	1,133,000	849,494	298,415	266,192	284,887
Mar-20	1,312,000	1,215,269	410,779	403,277	401,213
Production 2020 (ytd) (kWh)	3,788,000	3,031,123	1,071,390	1,013,736	945,997
Total Production (kWh)*	12,036,000	10,433,443	3,621,795	3,507,692	3,303,956
Capacity Factor*	26.40%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

March-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events*

Date	Event	Duration (hr)	Turbine
April-2020	Goldwind 6 Month Maintenance	~8	WG 1
April-2020	Goldwind 6 Month Maintenance	~8	WG 2
April-2020	Goldwind 6 Month Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/5/2020	Owner/Operator Maintenance	Unplanned	4.82	WG 1
3/24/2020	Owner/Operator Maintenance	Unplanned	5.69	WG 2

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WG1	100.00%	100.00%
WG2	100.00%	99.99%
WG3	99.80%	93.64%
Avg	99.93%	97.88%

Downtime (hr)	This Month	Year To Date
WG1	7.28	185.74
WG2	7.63	216.17
WG3	3.46	296.25
Total	18.37	698.16

G. Billed Data

Meter Reading (Date/Time)	3/29/2020 12:00 AM
Meter To Date Produced	15,497,591 kWh
Meter To Date Consumed	60,320 kWh
Last Reading Produced	14,435,650 kWh
Last Reading Consumed	57,577 kWh
Billed kWh	1,059,199 kWh
Next Meter Reading	4/29/2020 12:00 AM

H. Report Notes and Comments

*Goldwind Maintenance moved to April.
**Goldwind Availability and Downtime under dispute.
***WG3 production for December 2019 and January 2020 is an estimate due to communication issue.