




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Mar-19	1,242,761	1,352,210	484,800	453,230	414,180
Apr-19	1,447,248	1,456,800	503,290	479,380	474,130
May-19	1,010,966	1,102,180	380,120	364,910	357,150
Jun-19	668,411	934,460	320,720	307,820	305,920
Jul-19	638,097	575,390	191,700	191,910	191,780
Aug-19	577,992	634,650	218,690	210,230	205,730
Sep-19	631,697	732,500	253,580	232,050	246,870
Oct-19	1,003,602	1,248,994	421,770	423,766	403,458
Nov-19	1,395,914	1,124,700	383,460	368,940	372,300
Dec-19	1,278,858	1,370,840	492,520	451,610	426,710
Jan-20	1,332,437	1,346,410	458,880	440,070	447,460
Feb-20	1,157,019	1,226,310	419,290	406,120	400,900
Mar-20	1,242,761	1,324,950	450,850	430,520	443,580
Production 2020 (ytd) (kWh)	3,732,216	3,897,670	1,329,020	1,276,710	1,291,940
Total Production (kWh)*	12,384,999	13,078,184	4,494,870	4,307,326	4,275,988
Capacity Factor*	33.09%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

March-2020



Monthly Report
March-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2020	Goldwind 8 Year Maintenance	~15	WTG A
September-2020	Goldwind 8 Year Maintenance	~15	WTG B
September-2020	Goldwind 8 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/17/2020	Goldwind 7.5 Year Maintenance	Planned	4.75	WTG A
3/19/2020	Goldwind 7.5 Year Maintenance	Planned	5.43	WTG B
3/23/2020	Goldwind 7.5 Year Maintenance	Planned	3.18	WTG C

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	100.00%
WTG C	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG A	7.33	25.67
WTG B	8.01	36.58
WTG C	5.76	79.87
Total	21.10	142.12

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2020 Annual
WTG A	12.78	12.79
WTG B	12.74	12.73
WTG C	13.56	13.48
Estimated	14.92	13.39

Capacity Factor (%)	This Month	2020 Annual
WTG A	40.40%	40.57%
WTG B	38.58%	38.97%
WTG C	39.75%	39.44%
Low Estimate	35.10%	28.72%

H. Report Notes and Comments

*WTG C total production includes estimated production for April 1-7 2019 due to meter malfunction.