




A. Site Energy Production Summary

		Energy Production (kWh)				*	
		Site		By Turbine			
		Expected Production	Actual Production	WTG A	WTG B		WTG C
	Apr-19	1,447,248	1,456,800	503,290	479,380	474,130	
	May-19	1,010,966	1,102,180	380,120	364,910	357,150	
	Jun-19	668,411	934,460	320,720	307,820	305,920	
	Jul-19	638,097	575,390	191,700	191,910	191,780	
	Aug-19	577,992	634,650	218,690	210,230	205,730	
	Sep-19	631,697	732,500	253,580	232,050	246,870	
	Oct-19	1,003,602	1,248,994	421,770	423,766	403,458	
	Nov-19	1,395,914	1,124,700	383,460	368,940	372,300	
	Dec-19	1,278,858	1,370,840	492,520	451,610	426,710	
	Jan-20	1,332,437	1,346,410	458,880	440,070	447,460	
	Feb-20	1,157,019	1,226,310	419,290	406,120	400,900	
	Mar-20	1,242,761	1,324,950	450,850	430,520	443,580	
	Apr-20	1,447,248	1,232,926	423,174	392,024	417,728	
Production 2020 (ytd) (kWh)		5,179,464	5,130,596	1,752,194	1,668,734	1,709,668	
Total Production (kWh)*		12,384,999	12,854,310	4,414,754	4,219,970	4,219,586	
Capacity Factor*		32.52%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

April-2020



Monthly Report
April-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2020	Goldwind 8 Year Maintenance	~15	WTG A
September-2020	Goldwind 8 Year Maintenance	~15	WTG B
September-2020	Goldwind 8 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/24-25/2020	Grid Fault	Unplanned	11.00	WTG A
4/24-25/2020	Grid Fault	Unplanned	9.69	WTG B
4/24-25/2020	Grid Fault	Unplanned	9.45	WTG C
4/25/2020	Tower Base Cooling Fan Error	Unplanned	9.50	WTG B

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	98.68%	99.67%
WTG C	100.00%	100.00%
Avg	99.56%	99.89%

Downtime (hr)	This Month	Year To Date
WTG A	11.00	36.67
WTG B	19.19	55.77
WTG C	9.45	89.32
Total	39.64	181.76

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2020 Annual
WTG A	12.76	12.78
WTG B	12.60	12.69
WTG C	13.53	13.49
Estimated	16.62	13.39

Capacity Factor (%)	This Month	2020 Annual
WTG A	39.18%	40.22%
WTG B	36.30%	38.31%
WTG C	38.68%	39.25%
Low Estimate	42.22%	28.72%

H. Report Notes and Comments

*WTG C total production includes estimated production for April 1-7 2019 due to meter malfunction.