


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Apr-19	949,000	852,957	427,080	425,877
May-19	603,000	615,463	306,237	309,226
Jun-19	422,000	474,817	240,372	234,445
Jul-19	383,000	338,373	171,861	166,512
Aug-19	402,000	355,979	180,172	175,807
Sep-19	346,000	403,384	203,853	199,531
Oct-19	649,000	709,389	354,865	354,524
Nov-19	846,000	669,872	338,584	331,288
Dec-19	1,022,000	943,766	481,616	462,150
Jan-20	867,000	820,679	407,059	413,620
Feb-20	908,000	670,274	317,389	352,885
Mar-20	803,000	795,295	400,369	394,926
Apr-20	949,000	706,174	357,900	348,274
Production 2020 (ytd) (kWh)	3,527,000	2,992,422	1,482,717	1,509,705
Total Production (kWh)*	8,200,000	7,503,465	3,760,277	3,743,188
Capacity Factor*	28.47%		*Value calculated over the last 12 months	

B. Site Energy Production Graph

April-2020



Monthly Report

April-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 5 Year Maintenance	~15	W1
October-2020	Goldwind 5 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/6/2020	Owner/Operator Maintenance	Unplanned	7.75	W1
4/15/2020	Goldwind 4.5 Year Maintenance	Planned	1.81	W1
4/16/2020	Goldwind 4.5 Year Maintenance	Planned	3.21	W2
4/17/2020	Goldwind 4.5 Year Maintenance	Planned	3.95	W1
4/17/2020	Goldwind 4.5 Year Maintenance	Planned	1.13	W2
4/20/2020	Owner/Operator Maintenance	Unplanned	7.55	W2
4/22/2020	Owner/Operator Maintenance	Unplanned	4.07	W2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.64%	99.91%
W2	99.62%	99.90%
Avg	99.63%	99.91%

Downtime (hr)	This Month	Year To Date
W1	19.37	179.51
W2	20.39	70.16
Total	39.76	249.67

G. Billed Data

Meter Reading (Date/Time)	4/29/2020 12:00 AM
Meter To Date Produced	33,508,180 kWh
Meter To Date Consumed	66,689 kWh
Last Reading Produced	32,754,792 kWh
Last Reading Consumed	65,626 kWh
Billed kWh	752,324 kWh
Next Meter Reading	5/29/2020 12:00 AM

H. Report Notes and Comments