


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Apr-19	1,176,000	1,017,622	347,943	331,201	338,478
May-19	927,000	753,487	261,344	247,282	244,861
Jun-19	634,000	653,072	224,916	205,888	222,268
Jul-19	527,000	357,677	119,328	116,242	122,107
Aug-19	449,000	423,670	145,657	134,069	143,944
Sep-19	610,000	414,660	141,275	131,797	141,588
Oct-19	990,000	916,038	308,623	294,939	312,476
Nov-19	1,123,000	846,849	291,098	273,259	282,492
Dec-19	1,153,000	1,139,609	398,017	365,419	376,173
Jan-20	1,306,000	1,063,984	370,096	346,270	347,618
Feb-20	1,137,000	767,713	286,395	246,834	234,484
Mar-20	1,134,000	1,101,462	378,775	354,544	368,143
Apr-20	1,176,000	1,028,204	354,270	335,252	338,682
Production 2020 (ytd) (kWh)	4,753,000	3,961,363	1,389,536	1,282,900	1,288,927
Total Production (kWh)*	11,166,000	9,466,425	3,279,794	3,051,795	3,134,836
Capacity Factor*	23.95%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

April-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events8

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 3 Year Maintenance	~15	W1
October-2020	Goldwind 3 Year Maintenance	~15	W2
October-2020	Goldwind 3 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/6/2020	Goldwind 2.5 Year Maintenance	Planned	2.66	W1
4/8/2020	Goldwind 2.5 Year Maintenance	Planned	3.61	W2
4/14/2020	Goldwind 2.5 Year Maintenance	Planned	1.90	W1, W2
4/14/2020	Goldwind 2.5 Year Maintenance	Planned	6.69	W3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.94%
W2	100.00%	99.64%
W3	100.00%	99.99%
Avg	100.00%	99.86%

Downtime (hr)	This Month	Year To Date
W1	4.56	103.41
W2	5.51	143.92
W3	6.69	197.94
Total	16.76	445.27

G. Billed Data

Meter Reading (Date/Time)	4/21/2020 12:00 AM
Meter To Date Produced	23,174,690 kWh
Meter To Date Consumed	67,105 kWh
Last Reading Produced	22,296,661 kWh
Last Reading Consumed	64,975 kWh
Billed kWh	875,899 kWh
Next Meter Reading	5/21/2020 12:00 AM

H. Report Notes and Comments