



Monthly Report
May-2020




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
May-19	1,010,966	1,102,180	380,120	364,910	357,150
Jun-19	668,411	934,460	320,720	307,820	305,920
Jul-19	638,097	575,390	191,700	191,910	191,780
Aug-19	577,992	634,650	218,690	210,230	205,730
Sep-19	631,697	732,500	253,580	232,050	246,870
Oct-19	1,003,602	1,248,994	421,770	423,766	403,458
Nov-19	1,395,914	1,124,700	383,460	368,940	372,300
Dec-19	1,278,858	1,370,840	492,520	451,610	426,710
Jan-20	1,332,437	1,346,410	458,880	440,070	447,460
Feb-20	1,157,019	1,226,310	419,290	406,120	400,900
Mar-20	1,242,761	1,324,950	450,850	430,520	443,580
Apr-20	1,447,248	1,232,926	423,174	392,024	417,728
May-20	1,010,966	1,138,690	392,230	364,170	382,290
Production 2020 (ytd) (kWh)	6,190,430	6,269,286	2,144,424	2,032,904	2,091,958
Total Production (kWh)*	12,384,999	12,890,820	4,426,864	4,219,230	4,244,726
Capacity Factor*	32.61%		*Value calculated over the last 12 months		

B. Site Energy Production Graph

May-2020



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2020	Goldwind 8 Year Maintenance	~15	WTG A
September-2020	Goldwind 8 Year Maintenance	~15	WTG B
September-2020	Goldwind 8 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	99.74%
WTG C	100.00%	100.00%
Avg	100.00%	99.91%

Downtime (hr)	This Month	Year To Date
WTG A	0	36.67
WTG B	0	55.77
WTG C	0	89.32
Total	0	181.76

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2020 Annual
WTG A	12.20	12.66
WTG B	11.97	12.55
WTG C	12.96	13.38
Estimated	13.57	13.39

Capacity Factor (%)	This Month	2020 Annual
WTG A	35.15%	39.19%
WTG B	32.63%	37.15%
WTG C	34.26%	38.23%
Low Estimate	28.39%	28.72%

H. Report Notes and Comments