



BALL CORPORATION - ZEPHYR WIND PROJECT

North Findlay Wind Campus, Findlay, OH




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3	
May-19	900,000	674,985	237,304	222,891	214,790	*
Jun-19	628,000	682,994	232,437	224,872	225,685	*
Jul-19	571,000	469,744	167,832	151,963	149,949	
Aug-19	598,000	513,686	177,673	167,452	168,561	
Sep-19	515,000	585,768	205,203	193,838	186,727	
Oct-19	966,000	1,039,656	350,721	348,791	340,144	
Nov-19	1,262,000	889,667	312,289	296,145	281,233	
Dec-19	1,524,000	1,392,651	483,293	460,120	449,238	
Jan-20	1,291,000	1,187,158	410,228	396,206	380,724	
Feb-20	1,355,000	963,876	349,562	308,005	306,309	
Mar-20	1,197,000	1,162,213	396,502	388,972	376,739	
Apr-20	1,415,000	1,077,278	363,770	357,740	355,768	
May-20	900,000	924,506	311,078	306,313	307,115	
Production 2020 (ytd) (kWh)	6,158,000	5,315,031	1,831,140	1,757,236	1,726,655	
Total Production (kWh)*	12,222,000	10,889,197	3,760,588	3,600,417	3,528,192	
Capacity Factor*	27.55%		*Value calculated over the last 12 months			

B. Site Energy Production Graph

May-2020



Monthly Report

May-2020

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2020	Goldwind 4.5 Year Maintenance	~8	Z1
October-2020	Goldwind 4.5 Year Maintenance	~8	Z2
October-2020	Goldwind 4.5 Year Maintenance	~8	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/4/2020	Owner/Operator Preventative Maintenance	Unplanned	7.23	Z1
5/27/2020	Owner/Operator Preventative Maintenance	Unplanned	6.69	Z2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	100.00%	99.81%
Z2	100.00%	99.99%
Z3	100.00%	100.00%
Avg	100.00%	99.93%

Downtime (hr)	This Month	Year To Date
Z1	15.17	86.12
Z2	7.19	123.15
Z3	0.25	99.23
Total	22.61	308.50

G. Billed Data

Meter Reading (Date/Time)	5/19/2020 12:00 AM
Meter To Date Produced	48,226,722 kWh
Meter To Date Consumed	59,694 kWh
Last Reading Produced	47,070,605 kWh
Last Reading Consumed	58,876 kWh
Billed kWh	1,155,299 kWh
Next Meter Reading	6/18/2020 12:00 AM

H. Report Notes and Comments

*Z3 production total for May and June 2019 is an estimate due to loss of communications.